

SEWERAGE SYSTEM STANDARD PRACTICE MANUAL

September, 2006

Issued By:

Ministry of Health
Population Health and Wellness
Health Protection
4th Floor, 1515 Blanshard Street
Victoria, BC V8W 3C8

This page is intentionally blank.

Table of Contents

1	Purpose and Content of this Manual	5
1.1	Purpose.....	5
1.2	Content	6
2	Administrative.....	6
2.1	Administrative Process.....	6
2.2	Filing Cancellation	7
2.3	Filing Notification Referrals	7
2.4	Privacy.....	7
2.5	Other Administrative Jurisdictions.....	7
2.6	Restrictive Covenants.....	7
2.7	Use of Adjacent Property	8
2.8	Easements and Covenants	8
2.9	New Systems	8
2.10	Repairs and Replacements	8
2.10.1	Component Repair or Replacement	8
2.10.2	System Repair or Replacement	9
2.11	Seasonal Dwellings with No Hydro Connection.....	9
2.12	Multiple Homes on Same Property	10
3	Roles and Responsibilities	10
3.1	Health Authority.....	10
3.2	Authorized Person	10
3.3	Sewerage System Owner.....	11
4	Wastewater Flow Rates	11
4.1	Design Flows.....	11
4.2	Minimum Design Flow Rates for Residences	12
4.2.1	Flow Reduction Devices	12
4.3	Garbage Grinders (Garburators).....	12
4.3.1	Treatment	12
4.3.2	Distribution	12
4.4	Other Minimum Design Flow Rates	12
4.4.1	Design Non-Residential Waste Design Flows	13
5	Determination of Treatment and Disposal Requirements	19
5.1	Process Selection.....	19
5.2	Levels of Treatment	19
5.3	Site Constraints for Sewage Treatment Selection	19
5.4	Selecting a Treatment System Based on Site Constraint (SC).....	21
5.5	Required Vertical Separation	21
5.6	Hydraulic Loading Rates.....	22
5.7	Setback Requirements.....	26
6	Piping	27
6.1	Design Considerations	27
6.2	Installation Standards	27
6.3	Requirements for Materials	28
7	Raw Wastewater Conveyance.....	30

8	Septic Tanks (Type 1) and Sewage Effluent Tanks	30
8.1	Design Considerations	30
8.1.1	General	30
8.1.2	Septic Tank Volume Requirements.....	31
8.1.3	Watertightness Testing.....	33
8.2	Installation Standards	33
8.2.1	General	33
8.2.2	Installation.....	33
	Septic Tank Abandonment.....	34
9	Type 2 Treatment Plants.....	34
9.1	Design Considerations	34
9.2	Installation Standards	35
9.3	Requirements for Materials.....	35
10	Type 3 Treatment Plants.....	36
10.1	Design Considerations	36
11	Effluent Distribution.....	36
11.1	Soil Absorption Areas	36
11.2	Gravity Flow Subsurface Distribution	36
11.2.1	Construction Criteria.....	36
11.2.2	Trench Construction Criteria.....	37
11.2.3	Effluent Infiltration Monitoring Well	37
11.2.4	Trench Sizing	37
11.2.5	Trench Dimensions	37
11.2.6	Distribution Box.....	37
11.3	Aggregate (Drain Rock) Criteria.....	38
11.4	Construction	38
11.5	Pressurized Effluent Conveyance.....	42
11.5.1	Pump Tank	42
11.5.2	Pump Tank Sizing	42
11.5.3	Effluent Pump	43
11.5.4	Plumbing Criteria	43
11.5.5	Electrical Criteria	43
11.5.6	Float Switch Criteria	44
11.5.7	Effluent Pump Filtration	44
11.5.8	Inspection, Monitoring and Maintenance.....	44
11.6	Pressure Distribution Construction	45
11.7	Low-Pressure Effluent Distribution	45
11.7.1	Design Criteria	45
11.7.2	Orifice Orientation	46
11.7.3	Distribution Sizing	46
11.7.4	Pressure Test	47
11.7.5	Maintenance	47
11.7.6	Cold Weather Criteria	47
12	Seepage Beds.....	47
12.1.1	Site Criteria	47
12.1.2	Construction Criteria.....	47
12.1.3	Bed Sizing	47
12.1.4	Bed Dimensions	48

12.2 Aggregate (Drain Rock) Criteria.....	48
12.3 Construction	48
13 Mounds.....	49
13.1 Site Criteria	49
13.2 Construction Criteria.....	49
13.3 Fill Material Specifications	50
13.4 Mound Sizing.....	50
13.5 Construction	50
13.6 Inspection, Monitoring and Maintenance.....	51
14 Gravelless Aggregate Effluent Dispersal Systems	51
14.1 Proprietary Gravelless Systems.....	51
15 Sloping Sites.....	51
15.1 Slope Construction	52
16 Lagoons	52
16.1 General	52
16.2 Siting Criteria	53
16.3 Construction Criteria.....	53
16.3.1 Gravity Flow Discharge	54
16.3.2 Pumped Discharge	54
16.3.3 Lagoon Sizing	55
16.3.4 Construction	56
16.3.5 Fencing.....	57
16.4 Installation Standards	57
16.5 Maintenance	57
17 Maintenance and Inspection	52
17.1 Requirements of the Sewerage System Regulation.....	58
17.1.1 Owner.....	58
17.1.2 Maintenance Provider	58
17.2 Maintenance Plan	58
17.3 Frequency of Inspection and Maintenance.....	59
17.4 Flow Trials	60

List of Figures

Figure 5-1: Vertical separation between the infiltrative surface and the restrictive layer.	22
Figure 8-1: Compartmentalized septic tank.....	31
Figure 8-2: Septic tank with multiple chambers provided by individual tanks.	31
Figure 11-1: Distribution box	38
Figure 11-2: Trench dispersal layout.....	39
Figure 11-3: Pressure distribution system	45
Figure 11-4: Bed pressure dispersal layout	49
Figure 15-1: Trench depth variance on sloped site.....	52
Figure F-1: Cross section and plan views of a mound system on a sloping site.....	F-7

List of Tables

Table 4-1:	Minimum design flow rates for residences	12
Table 4-2:	Other minimum design flow rates	14
Table 5-1:	Site constraints	20
Table 5-2:	Required vertical separation	22
Table 5-3:	Wastewater Loading Rates for Residential Strength Wastewater	24
Table 5-4:	Horizontal setback distances	26
Table 6-1:	Cleanout sizing and spacing	28
Table 6-2:	Piping standards	29
Table 8-1:	Septic tank volume requirements	32
Table 11-1:	Linear Loading Rates for Residential Strength Wastewater: METRIC	40
Table 11-1:	Linear Loading Rates for Residential Strength Wastewater: IMPERIAL	41
Table 13-1:	Mound sand particle sizing criteria	50
Table 16-1:	Lagoon cell sizing requirements	55
Table 17-1:	Inspection frequencies	59
Table 17-2:	Estimated septic tank pumping frequencies in years	60
Table D-1:	Method 3 — Calculating design soil hydraulic loading rate (HLR) for a drainfield from the soil's field saturated hydraulic conductivity	D-4
Table E-1:	Lateral design table	E-7
Table E-2:	Orifice discharge rates in gallons per minute (gpm)	E-10
Table E-3a:	Maximum manifold length in feet for orifice diameters of $\frac{3}{16}$ in. and up with minimum 2 feet of residual head	E-11
Table E-3b:	Maximum manifold length in feet for orifice diameters of $\frac{1}{8}$ in. and $\frac{5}{32}$ in. with minimum 5 feet of residual head	E-12
Table E-4:	Constant "K" values	E-13
Table E-5:	Equivalent length of pipe in feet of friction loss for PVC fittings	E-13
Table E-6:	Volume of pipes in gallons per foot (gpf)	E-13
Table F-1:	Sand fill loading rates as a function of level of treatment	F-3
Table F-2:	Mound sand and C33 fine aggregate sieve analysis	F-3
Table F-3:	Selection of a soil hydraulic loading rate (HLR)	F-4
Table F-4:	Linear hydraulic loading rates for mound systems	F-13
Table F-5:	Down slope and up slope correction factors	F-14
Table G-1:	Maximum flow trial volumes relative to number of bedrooms and design flow ...	G-2
Table H-2:	Depth change equivalent to four L in round risers of various interior diameters. .	H-6
Table H-3:	Depth change equivalent to four L in square risers of given interior dimensions.	H-6

List of Appendices

Appendix A:	Sewerage System Regulation	A-1
Appendix B:	Procedure for Percolation Test	B-1
Appendix C:	Recommendation for Field Tests of Soil Permeability	C-1
Appendix D:	Calculating Design HLR from Soil Hydraulic Conductivity	D-1
Appendix E:	Pressure Distribution Network Design	E-1
Appendix F:	Mound Systems	F-1
Appendix G:	Flow Trials	G-1
Appendix H:	Testing	H-1
Endnotes		

1 PURPOSE AND CONTENT OF THIS MANUAL

Note: This manual must be followed by Registered Onsite Wastewater Practitioners registered with ASTTBC. Professionals, as defined in the Sewerage System Regulation (326/2004), may exercise professional discretion within their area of expertise in using this manual for the design, installation and maintenance of sewerage systems covered by this manual.

1.1 Purpose

The Sewerage System Regulation under the *Health Act*, (See Appendix A), applies to the construction, and maintenance of:

- a holding tank;
- a sewerage system that serves a single family residence or a duplex;
- a sewerage system or combination of sewerage systems with a combined design daily domestic sewage flow of less than 22,700 litres that serves structures on a single parcel; and,
- combination of sewerage systems with a combined design daily domestic sewage flow of less than 22,700 litres that serves structures on one or more parcels or strata lots or on a shared interest.

The Sewerage System Regulation applies only to domestic sewage, which includes:

- human excreta and
- waterborne waste from the preparation and consumption of food and drink, dishwashing, bathing, showering, and general household cleaning and laundry, except waterborne waste from a self-service laundromat.

Systems other than holding tanks and privies are referred to as “sewerage systems” and are the subject of this Standard Practice Manual.

The Sewerage System Regulation requires an “Authorized Person” as defined in the Regulation to file information about a sewerage system and a letter of certification after construction to the Health Authority, including assurance that the plans and specifications are consistent with “standard practice.” The Authorized Person may refer to this publication, “Sewerage System Standard Practice Manual,” which will be amended from time to time.

The “Authorized Person” is required in the Sewerage System Regulation to provide the owner with a maintenance plan that is consistent with standard practice.

1.2 Content

The contents of this manual reflects the mandate of the Sewerage System Regulation.

HOLDING TANKS are regulated by the Sewerage System Regulation.

PRIVIES are NOT regulated by the Sewerage System Regulation.

The Sewerage System Regulation prohibits discharge of domestic sewage or effluent into surface waters or tidal water or onto land. The provisions of the Municipal Sewage Regulation under the *Waste Management Act* apply to these discharges.

Neither the Sewerage System Regulation nor the Standard Practice Manual provides standards related to approval for the subdivision of land.

This manual sets out standards for sewerage systems handling less than 22,700 litres per day of domestic sewage, and which include the following methods of treatment and disposal:

- septic tanks (Type 1);
- sewage treatment plants (Type 2);
- disposal fields;
- treatment mounds; and,
- sewage lagoons (without effluent outlet).

The Sewerage System Regulation prohibits a person from constructing or maintaining a sewerage system that uses an advanced treatment system (see Type 3 in Section 4.1 of the Regulation), or is designed for an estimated daily domestic sewage flow of more than 9,100 litres, unless supervised by a “Professional” (as defined in S. 7(3) of the Regulation).

2 ADMINISTRATIVE

2.1 Administrative Process

Prior to construction, alterations or repairs to a sewerage system, an Authorized Person will file the following information with the Health Authority:

- property legal description;
- property owner information;
- the site and soil investigation report;
- sewerage system design and layout; and,
- plans and specifications of the sewerage system.

Plans and specifications and other sewerage system information will have the Authorized Person’s seal affixed.

The Authorized Person will submit all information in a format acceptable to the Health Authority. A standard form is available from local Health Authorities.

Within thirty days after completion of the sewerage system, the Authorized Person will:

- file a letter certifying compliance with the Regulation to the Health Authority, and
- provide the owner and Health Authority with the sewerage system operations, specifications, commissioning details (start-up), maintenance plan and the name of a possible certified maintenance provider.

If the AP does not file a letter of certification within one year of filing initial information about the sewerage system, the Authorized Person must not start or continue construction of the sewerage system until filing new information.

2.2 Filing Cancellation

A file can be cancelled when:

- information is determined to be false and/or misleading, and
- changes to the application are sufficient to warrant cancellation.

At the time of cancellation, the Health Authority will notify any additional authorities having jurisdiction over the affected property.

2.3 Filing Notification Referrals

The Health Authority may notify the local building inspection department or local government authority about the filed sewerage system.

Notification may not be required when:

- wastewater system repairs or alterations of an existing developed property will not affect the building envelope or change the physical placement of the system.

2.4 Privacy

The Freedom of Information and Protection of Privacy Act will govern the information provided, as part of the filing process, and will be released in accordance with the provision of the *Act*.

2.5 Other Administrative Jurisdictions

It is the responsibility of the Authorized Person to:

- ensure that all local zoning and/or bylaws are complied with; and,
- notify the Health Authority regarding any conflicts arising from failure to comply with local zoning and/or bylaws.

2.6 Restrictive Covenants

The Authorized Person(s) will need to ensure that:

- the filing under Section 8 of the Regulation includes a copy of and complies with, any covenants attached to the property title.

2.7 Use of Adjacent Property

The use of a sewerage system on adjacent property must:

- meet all conditions of the Regulation; and,
- be protected by easements and covenants.

A sewerage system can be constructed on adjacent property when:

- there is no suitable area for construction or repair on the primary property; and,
- a system needs repairing and there is no reserve area for the new field.

A sewerage system can be connected to another sewerage system upon an adjacent property when:

- there is no suitable area for construction or repair on the primary property;
- the sewerage system on the adjacent lot can adequately accept the additional load; and,
- the sewerage system on the adjacent lot will not create a problem or contributes to a health risk.

2.8 Easements and Covenants

The use of an adjacent property will need to be:

- registered with the local Health Authority; and
- secured by an easement protected by covenant that is prepared by a qualified lawyer.

Any changes to registered covenant(s) will require agreement by the Health Authority.

2.9 New Systems

All systems subject to the Sewerage System Regulation must meet or exceed the standards outlined in this manual unless the design, installation and/or maintenance is supervised by a Professional within their scope of practice and exercising professional discretion within their area of expertise.

2.10 Repairs and Replacements

Where a sewerage system constructed prior to May 31, 2005 is in need of repair or replacement and the work cannot be done in accordance with the Sewerage System Standard Practice manual, the authorized person may deviate from the manual only to the degree necessary to repair or replace the system in a manner that will not create a health hazard.

In emergency situations, an authorized person may carry out the works necessary to eliminate health hazard arising from failed or failing systems and to maintain the function of that system until permanent repairs or replacements can be carried out in accordance with the Standard Practice manual.

Where the site constraints in Table 5-1 dictate, a Professional must supervise the repair or replacement of a system.

Existing systems that are subject to repairs or replacement shall be brought into compliance with the Sewerage System Standard Practice manual where practicable.

All regulatory filing provisions apply

2.10.1 Component Repair or Replacement

Authorized Persons will *not* be required to prepare and submit a “filing” document to the Health Authority for the repair or replacement of any minor parts of the system such as:

- 2 liquid level float switch;
- 3 pump of exact same brand and model;
- 4 level of D Box adjustment;
- 5 tank inlet or outlet fittings;
- 6 septic tank effluent filters cleaning or replacing;
- 7 dispersal field lines flushing or vacuuming; or,
- 8 a dispersal field line or pipe section replacement when the pipe is broken or damaged to the point where it is not working or likely to work.

2.10.2 System Repair or Replacement

Authorized Persons *must* prepare and submit a “filing” document to the Health Authority for the repair or replacement of any major item of the system such as adding to or replacing septic/pump tanks, dispersal systems (trenches, beds, mounds), and lagoon cells. Where the existing system has failed due to increases in daily sewage flow rates the repair or replacement shall be made to accommodate the increase in daily sewage flow.

2.11 Seasonal Dwellings with No Hydro Connection

Seasonal use systems must be installed in compliance with the Sewerage System Standard Practice manual.

If it is not possible to apply this manual because of the site constraints, seasonal use of the property and limited water use, the Authorized Person may deviate from the manual for construction methods, only to the degree necessary to create a system that does not or will not create a health hazard.

Type 2 or Type 3 systems should not be used for seasonal dwellings as these systems are typically dependant on hydro for electrical components and may rely on biological processes that cannot be sustained under seasonal conditions.

To determine the degree of site constraint(s) refer to Table 5-1 (Site Constraints). Where site constraints dictate, a Professional must supervise the repair, replacement or installation of a system.

2.12 Multiple Homes on Same Property

When two homes will occupy one property the Authorized Person(s) will ensure that the single or combined sewerage system complies with the Sewerage System Regulation and Sewerage System Standard Practice Manual.

3 ROLES AND RESPONSIBILITIES

3.1 Health Authority

Health Authorities have statutory authority under the *Health Authorities Act* to:

- administer the Sewerage System Regulation;
- carry out legal remedies such as orders or tickets;
- accept documents for filing and certification of systems;
- ensure documents meet the Regulation;
- ensure that only an Authorized Person construct or maintain the installed sewerage system; and,
- inspect and take corrective action to alleviate health hazards related to onsite wastewater systems.

3.2 Authorized Person

An Authorized Person:

- has specific understanding of all of the integrated components and their application for the proper performance of a sewerage system;
- is familiar with the practice of developing plans, details, specifications, instructions, or inspections in the analysis of soil morphology, hydrology, geology, site layout, collection, conveyance, dispersal, sewage treatment technologies and their classifications;
- has a comprehensive knowledge of how the sewerage system being designed works and has the ability to evaluate and repair systems;
- is responsible for correctly identifying site conditions and assigning wastewater loading rates;
- prepares a comprehensive written site/soil evaluation report;
- uses the site/soil evaluation report to plan the sewerage system, including placement of components, tank sizing, effluent quality classification, treatment process, sub-surface effluent dispersal method, sub-surface effluent dispersal sizing and reserve area requirements.

- in consultation with the property owner, applies good judgment to prepare a plan that addresses the limitations of the property in compliance with the Sewerage System Regulation and with regard to the Standard Practice Manual;
- ensures that sewerage systems are planned, installed and operated ethically, competently and with due diligence;
- provides documentation in a clear format and files plans and specifications of the sewerage system in a manner acceptable to the Health Authority;
- ensures plans and specifications are consistent with the Sewerage System Standard Practice Manual;
- when the sewerage system is completed, provides a letter of certification to the Health Authority that the sewerage system was installed in accordance with filed plans and standard practices;
- starts and tests the sewerage system to verify that all equipment is functioning as intended; and,
- provides the homeowner and the Health Authority with the sewerage system maintenance plan.
- A maintenance plan is a set of instructions for maintaining a sewerage system that, if followed, will ensure that the sewerage system does not cause, or contribute to, a health hazard.

3.3 Sewerage System Owner

The sewerage system owner:

- ensures the system is operated correctly (in accordance with the maintenance plan);
- ensures maintenance is carried out on the system in accordance with the maintenance plan provided by the Authorized Person;
- keeps a record of all maintenance service performed;
- ensures compliance with the Regulations; and,
- ensures compliance with any local government policies and/or bylaws.

4 WASTEWATER FLOW RATES

4.1 Design Flows

The Authorized Person will determine the daily design flow rate using Table 4-1 (Minimum Design Flow Rates for Residences) and/or 4-2 (Other Minimum Design Flow Rates).

4.2 Minimum Design Flow Rates for Residences

The minimum flow rates for residences are in Table 4-1. These values include a safety factor.

The minimum design flow is a function of the number of bedrooms and the floor area as it is or could be finished for occupancy in the foreseeable future. To make sure the home is served by a sewerage system that is sized properly, the sewerage system must be based on the potential number of bedrooms in the house. Residential design flows will be used based on the declarations of developed living area provided by the building owner.

4.2.1 Flow Reduction Devices

There must be no reduction in the design flow rate for the use of flow reduction devices.

4.3 Garbage Grinders (Garburators)

4.3.1 Treatment

Where garbage grinders or garburators will be used, an increase in design flow of 50 percent is required for the treatment system.

4.3.2 Distribution

Distribution field design flow rates remain the same as for systems not using garburators.

Table 4-1: Minimum design flow rates for residences

Residence Size	Minimum Design Flow litres/gallons
1 and 2 bedroom unit up to 150 m ² 1,600 sq. ft.	1,136/250
3 bedroom unit up to 175 m ² 1,885 sq. ft.	1,363/300
4 bedroom unit up to 235 m ² 2,530 sq. ft.	1,700/375
5 bedroom unit up to 295 m ² 3,175 sq. ft.	2,045/450
6 bedroom unit up to 355 m ² 3,820 sq. ft.	2,500/550
For every additional m ² add	5/1

4.4 Other Minimum Design Flow Rates

It is the responsibility of the Authorized Person to determine a reasonable estimate of the typical flow rate from tables 4.1 and 4.2. For existing facilities, water or sewage flow measurements should also be considered.

Typical unit flows for many types of facilities are shown in Table 4-2. These values represent estimates of flow rates since each facility is unique.

Provision of flow measurement by metre, pump cycles and/or duration should be considered in the design of treatment and disposal facilities.

4.4.1 *Design Non-Residential Waste Design Flows*

Table 4-2 is used to determine the design flow for non-residential facilities. Where commercial kitchen equipment will be used in a facility, high strength waste is expected and a Professional is required for system design.

Table 4-2: Other minimum design flow rates

Institutional	Unit	Design Flow Rate (litres/gallon per day)
Assembly Halls no kitchen	Per person	8/1.75
Assembly Halls with kitchen	Per person	9/2
Church no kitchen	Per seat	26/6
Church with kitchen	Per seat	9/2
Church Suppers	Per person	45/10
Town Hall	Per seat	19/4
Fire station	Per person	19/4
Medical/Personal Care	Unit	Design Flow Rate (litres/gallon per day)
Hospital	Per bed	409/90
Including laundry	Per bed	750/165
Excluding laundry	Per bed	550/120
Hospital mental	Per bed	340/75
Add per employee	Per employee	23/5
Special care home	Per resident	136/30
Add per employee	Per employee	45/10
Medical Office Doctors nurses medical staff	Per person	273/60
Office staff add	Per person	73/16
Patient add	Per person	23/5
Dental Office	Per chair	757/166
Staff add	Per person	132/29
Schools	Unit	Design Flow Rate (litres/gallon per day)
Cafeteria & gym & shower	Per student	68/15
Cafeteria only	Per student	45/10
Gym only	Per student	68/15
Washrooms only	Per student	13.5/3
Elementary	Per student	26/6
High school	Per student	45/10
Junior High school	Per student	34/7.5
Boarding school	Per student	136/30
Boarding school	Per person	45/10
Prison	Unit	Design Flow Rate (litres/gallons per day)
Prison	Per inmate	136/30
Add for personnel	Per person	23/5

Food Service	Unit	Design Flow Rate (litres/gallons per day)
Bakery	Per employee	68/15
Bar/lounge	Per seat	125/27
Taverns/Bars/Lounges with minimal food service	Per seat	76/16
Restaurant	Per seat	31/7
Restaurant with food grinder	Per seat	23/5
24 hour restaurant	Per seat	189/41
24 hour highway	Per seat	265/58
24 hr highway & showers	Per seat	400/88
Kitchen & toilet waste only	Per seat	113/25
Kitchen and toilet waste only	Per patron	30/6.5
Banquet rooms	Per seat	30/6.5
Drive-in restaurant	Per seat	125/27
Night Club/Restaurant	Per seat	113/25
Dining rooms and lounges	Per m ² of dinning area	0.9/.2
Take out	Per m ²	0.19/.04
Banquet and Dining rooms	Per m ²	0.14/.03
Caterers	Per patron	45/10
Cafeteria	Per customer	4.5/.10
Coffee Shop	Per customer	19/4
Coffee shop	Per employee	36/8
Commercial Airport	Unit	Design Flow Rate (litres/gallons per day)
Airport	Per passenger	9/2
Airport	Per employee	41/9
Commercial Beauty Salon	Unit	Design Flow Rate (litres/gallons per day)
Beauty salon	Per station	400/88
Beauty salon	Per person	38/8
Commercial Veterinary	Unit	Design Flow Rate (litres/gallons per day)
Veterinary clinic (3 doctors or less) No boarding	Total	2,900/638
Veterinary clinic (3 doctor or less) Boarding	Total	5,700/1254
Dog kennel	Per enclosure	73/16

Commercial Laundry	Unit	Design Flow Rate (litres/gallons per day)
Laundromat	Per wash	168/37
Laundromat In apartment	Per machine	1,135/250
Department Store	Unit	Design Flow Rate (litres/gallons per day)
Department store	Per toilet room	1,513/333
Department store	Per employee	36/8
Shopping centre	Per employee	40/9
Shopping centre Washrooms	Per m ² of store space	5/1
Shopping centre Toilet rooms	Each	1,665/366
Centre with no café or laundry	Per m ²	7/1.5
Large dry goods centre	Per m ²	2/.45
Large supermarket & meat department	Per m ²	3/.6
Small dry goods store	Each	379/83
Commercial Automotive	Unit	Design Flow Rate (litres/gallons per day)
Automobile gas station	Per vehicle	22/5
Gas station	Per catch basin in floor	372/82
Gas station Double pump	Per unit	568/125
Automobile gas station island	Per island	2,000/440
Automobile gas station	Per vehicle	38/8
Car wash	Per car	189/42
Truck wash	Per truck	378/83
Commercial Hospitality	Unit	Design Flow Rate (litres/gallons per day)
Motel Bath & toilet only	Per person	118/26
Motel Full housekeeping	Per person	180/40
Motel	Per unit	318/70
Motel	Per housekeeping unit	455/100
Motel with Dining room	Per seat	122/27
Motel Bar and lounge	Per seat	68/15
Motel Bed & breakfast	Per person	27/6
Hotel	Per guest	136/30
Hotel	Per employee	36/8
Boarding house	Per resident	150/33
Dormitory Bunkhouse	Per person	91/20
Senior citizen home	Per resident	227/50
Day care centres	Per employee	73/16

Industrial/Office	Unit	Design Flow Rate (litres/gallons per day)
Industrial buildings Excluding industrial waste, cafeteria and showers	Per employee	45/10
Industrial buildings Excluding industrial waste, including showers	Per employee	75/16
Heavy Industry Excluding industrial waste, including cafeteria & shower	Per employee	132/29
Warehouse	Per employee	132/29
Industrial Park	Per acre	63,644/14000
Industrial Park	Per employee	68/15
Office No cafeteria	Per employee	50/11
Office Including cafeteria	Per employee	76/16
Town offices Office employees	Per employee	57/12.5
Town Offices Transients	Per person	19/4
Unspecified Office Space	Per m ²	613/135
Recreation Camping	Unit	Design Flow Rate (litres/gallons per day)
Campgrounds tents only	Per site	180/39
Campsites non year round	Per site	365/80
Having year round operation	Per site	545/120
Cabin Resort	Per person	159/35
Day camps no meal	Per person	38/8
Day camps with meals	Per person	68/15
Day camps	Per person	40/9
Construction camps flush toilets	Per person	189/41
Construction camps no flush toilets	Per person	123/27
Youth camps	Per person	189/41
Work camps	Per bed	227/50
Cottages & small seasonal dwellings	Per unit	189/41
Parks and Picnic Grounds	Unit	Design Flow Rate (litres/gallons per day)
Picnic & fairgrounds with bath houses, showers, toilets	Per person	38/8
Picnic & fairgrounds with toilet only	Per person	18/4
Beaches with showers & toilets	Per person	40/9
Visitor Centre	Per person	23/5
Country club Resident present	Per person	372/81
Country club Non resident	Per person	95/20
Country club Showers in use	Per fixture	1,800/395
Country club Water closet	Per fixture	550/120

Country club Lavatory	Per fixture	350/77
Country club Urinals – hand flush	Per fixture	350/77
Country clubs Showers	Per person	40/9
Country club	Per employee	50/11
Recreation General	Unit	Design Flow Rate (litres/gallons per day)
Dance halls day use	Per m ²	11/2.5
Dance halls restaurant	Per seat	15/3
Dance halls bar	Per seat	10/2
Dance hall bar & restaurant	Per patron	76/16
Theatre	Per seat	14/3
Recreation Sport	Unit	Design Flow Rate (litres/gallons per day)
Bowling Alleys bar or restaurant	Per alley	800/175
Bowling alleys no bar or restaurant	Per alley	105/23
Ice rink	Per seat	11/2.5
Ice rink	Per person	38/8
Stadium	Per seat	14/3
Swimming pool	Per customer	14/3
Swimming pool	Per m ²	50/11
Water slide park	Per visitor	5/1
Gym	Per person	38/8
Tennis/Racquetball no food	Per court	946/208
Ski areas no cafeteria	Per person	38/8
Ski areas with cafeteria	Per person	57/12
Outdoor sport facilities Toilet waste only	Per person	19/4

5 DETERMINATION OF TREATMENT AND DISPOSAL REQUIREMENTS

5.1 Process Selection

The selection of the treatment system and the effluent disposal system primarily depends on the design flow, the constraints of the site, the setback requirements and the land area available for the disposal system. Section 4 provides information on the design flow rates. Section 5 provides information on the other necessary considerations.

5.2 Levels of Treatment

The Sewerage System Regulation and the Standard Practice Manual are structured around specific levels of treatment prior to discharge into the ground. As defined in the Sewerage System Regulation:

- Type 1 is treatment by septic tank only;
- Type 2 is treatment that produces an effluent consistently containing less than 45 mg/L of total suspended solids and having a 5 day biochemical oxygen demand (BOD₅) of less than 45 mg/L; and,
- Type 3 is treatment that produces an effluent consistently containing less than 10 mg/L of total suspended solids and having a 5 day biochemical oxygen demand (BOD₅) of less than 10 mg/L, and a median fecal coliform density of less than 400 Colony Forming Units (cfu) per 100 mL.

5.3 Site Constraints for Sewage Treatment Selection

Use Table 5-1 (Site Constraints) following to select an onsite sewage treatment system. The overall class (1 to 4) is based on the worst case for each of the rows. For example, if the percolation rate, soil permeability, and land slope are all Class 1, and the depth to bedrock is Class 3, the overall class is Class 3 (Severe Constraints). In all cases, the sewerage system selected or designed must address all severe and very severe constraints identified from Table 5-1.

Table 5-1: Site constraints

	Site Constraint (SC) Refer to Explanation Below for Selecting a System Type			
Soil or Site Property	SC 1 Slight Constraints	SC 2 Moderate Constraints	SC 3 Severe Constraints	SC 4 Very Severe
Percolation Test Rate	3 to 20 minutes	21 to 30 minutes or 1 to 3 minutes	31 to 45 minutes or less than 1 minute	> 45 ⁽³⁾ minutes or < 1 minute
Soil Texture	sand, loamy sand, sandy loam, loam, silt, silt loam	gravelly sand, silty clay loam	very gravelly sand, sandy clay loam, clay loam	sandy clay, silty clay, clay
Soil Structure	Single grain (non-structured) or moderate to strong granular, blocky, columnar, or prismatic	Weak granular, blocky, columnar, or prismatic	Weak platy	Massive (non-structured), moderate to strong platy, wedge
Field Saturated Soil Permeability (Kfs)	9 to 75 cm/day	4.5 to 9 cm/day or 75 to 150 cm/day	2.0 to 4.5 cm/day or 150 to 300 cm/day	< 2.0 cm/day or > 300 cm/day
Land Slope	0% to 14%	15% to 24%	25% to 34%	> 35%
Depth of Native Soil Above the restrictive layer or Seasonal High Water Table ⁽¹⁾	> 90 cm (3 ft.)	60 to 90 cm (2-3 ft.)	0.30 to 0.60 cm (1-2 ft.)	0.15 to 0.30 cm (0.5-1 ft.)
Coarse Gravel Content ⁽²⁾	0% to 20%	20% to 50%	> 50%	—
Soil Texture	sand, loamy sand, sandy loam, loam, silt, silt loam	gravelly sand, silty clay loam	very gravelly sand, sandy clay loam, clay loam	sandy clay, silty clay, clay
Soil Structure	Single grain (non-structured) or moderate to strong granular, blocky, columnar, or prismatic	Weak granular, blocky, columnar, or prismatic	Weak platy	Massive (non-structured), moderate to strong platy, wedge

- (1) Seasonal High Water Table (SHWT): The high water table that persists in the soil for more than two weeks (US Dept. of Agriculture, 2001). The preferred procedure for determining the SHWT is through weekly or bi-weekly measurements in perforated or slotted standpipes. However, where this is not appropriate, the depth of the SHWT may be estimated from soil mottling and root depth.
- (2) Coarse Gravel: Portion of the soil consisting of gravel particles larger than 19 mm or ¾ inch. (Source: based on Epp, 1984)
- (3) Soils with percolation rates of greater than 45 minutes per 2.5 cm (1") that meet the criteria in section 16 may be considered for a lagoon system.

5.4 Selecting a Treatment System Based on Site Constraint (SC)ⁱ

SC 1:

Use a Type 1, 2, or 3 treatment system with gravity or pressure distribution to subsurface trenches, or pressure distribution to at-grade chambers.

SC 2:

Refer to Table 5.2 (Required Vertical Separation). Use either:

(a) Type 1 with pressure distribution to shallow trenches (as required to meet Table 5-2);

Type 1 with pressure distribution to a sand mound (as required to meet Table 5-2);

Type 2 with pressure distribution to shallow subsurface trenches or at grade chambers; or,

Type 3 with pressure distribution to subsurface trenches.

SC 3:

Use either:

(a) Type 2 with pressure distribution to shallow trenches (as required to meet Table 5-2);

(b) Type 2 with pressure distribution to a sand mound (as required to meet Table 5-2); or

(c) Type 3 system designed by a Professional.

SC 4:

Use either:

(a) Type 3 sewage treatment system with shallow trenches or a sand mound (as required to provide vertical separation) designed by a Professional, or,

(b) Lagoon system in accordance with section 16

5.5 Required Vertical Separation


Use Table 5-2 (Required Vertical Separation) to first determine the required depth of native soil prior to system installation, and then the required minimum allowable vertical separation, depending on the type of treatment system used.

The minimum vertical separation is the vertical distance from the infiltration surface (trench bottom) to the seasonal high water table or limiting layer (clay, rock), as in Figure 5-1 (Vertical separation between the infiltrative surface and the restrictive layer). With a sand mound, this vertical distance will include some native soil and some imported sand fill. With subsurface trenches or an at-grade system, this vertical distance includes only native soil.

Table 5-2: Required vertical separation

Sewage Treatment Used	Minimum Required Depth of Unsaturated Native Soil (prior to system installation)	
	(Centimetres)	(inches)
Type 1	60 cm	24"
Type 2	45 cm	18"
Type 3	30 cm	12"

	Minimum Allowable Vertical Separation (installed infiltrative surface to limiting layer)	
	(Centimetres)	(inches)
Type 1	90 cm	36"
Type 1	Pressure distribution 60 cm	24"
Type 2	60 cm	24"
Type 3	60 cm	24"

Figure 5-1: Vertical separation between the infiltrative surface and the restrictive layer.

5.6 Hydraulic Loading Rates

The effluent loading rate is the amount of effluent that can be applied each day over a basal (bottom) area of infiltrative surface without compromising the permeability or conductive capacity of the soil.

The sizing and configuration of subsurface soil-based treatment and dispersal processes is based on how the effluent moves away from and the rate at which it moves away from the distribution area.

For selection of a soil hydraulic loading rate for an onsite sewerage system use at least two of the three methods listed below, using Table 5-3 (Selection of a soil hydraulic loading rate). Appendices B, C and D respectively describe the required procedures for carrying out percolation tests, assessing soil texture and structure, and carrying out permeability tests to determine the soil hydraulic conductivity:

- percolation tests (*See Appendix B*);
- soil texture and structure assessments; and,
- soil hydraulic conductivity (K) tests (*See Appendix D*).

At least one of the methods used must be soil texture and structure.ⁱⁱ (*Also reference Appendix C: Recommendations for Field Tests of Soil Permeability.*)

If the two methods used lead to different hydraulic loading rates, use the most conservative rate — the lower hydraulic loading rate — resulting in a larger drainfield size.

Table 5-3: Wastewater Loading Rates for Residential Strength Wastewater

Soil Characteristics ¹			Percolation Rates (min/2.54 cm)	Field Saturated Hydraulic Conductivity (Kfs) mm/day	Wastewater Loading Rates gallons/ft ² /day (litres/m ² /day) ²		
Texture (USDA)	Structure				Type 1	Type 2	Type 3
	Shape	Grade					
Gravelly sand*	—	Single grain	< 2	> 2000	0.8 (39)	1.6 (78)	2.4 (117)
Coarse to medium sand/loamy sand	—	Single grain	2 – 5	1000 – 2000	0.7 (34)	1.4 (68)	2.1 (103)
Fine sand and fine loamy sand	—	Single grain	5 – 15	250 – 1000	0.6 (29)	1.2 (59)	1.8 (88)
Sandy loam	massive	structureless	20 – 30	125 – 250	0.3 (15)	0.45 (22)	0.6 (29)
	platy	weak			0.3 (15)	0.45 (22)	0.6 (29)
		moderate, strong			not recommended	not recommended	not recommended
	prismatic, blocky, granular	weak	10 – 20	250 – 500	0.4 (20)	0.7 (34)	1.0 (49)
		moderate, strong			0.5 (25)	1.0 (49)	1.5 (74)
Loam	massive	structureless	30 – 40	60 – 125	0.2 (10)	0.3 (15)	0.4 (20)
	platy	weak			0.2 (10)	0.3 (15)	0.4 (20)
		moderate, strong			not recommended	not recommended	not recommended
	prismatic, blocky, granular	weak	20 – 30	125 – 250	0.3 (15)	0.5 (24)	0.7 (34)
		moderate, strong			0.4 (20)	0.8 (39)	1.2 (59)
Silt loam, silt	massive	structureless	40 – 60	30 – 60	0.2 (10)	0.3 (15)	0.4 (20)
	platy	weak			0.2 (10)	0.3 (15)	0.4 (20)
		moderate, strong			not recommended	not recommended	not recommended
	prismatic, blocky, granular	weak	20 – 40	60 – 250	0.3 (15)	0.5 (24)	0.7 (34)
		moderate, strong			0.4 (20)	0.8 (39)	1.2 (59)
Clay loam, sandy clay loam, silty clay loam*	massive	structureless	60 – 90	15 – 30	not suitable	not suitable	not suitable
	platy	weak			not suitable	not recommended	not recommended
		moderate, strong			not suitable	not suitable	not suitable
	prismatic, blocky, granular	weak	40 – 60	30 – 60	0.2 (10)	0.3 (15)	0.4 (20)
		moderate, strong			0.3 (15)	0.45 (22)	0.6 (29)
Sandy clay, silty clay, clay* ³	massive	structureless	90 – > 120	< 5.0 – 60	not suitable	not suitable	not suitable
	platy	weak				not recommended	not recommended
		moderate, strong				not suitable	not suitable
	prismatic, blocky, granular	weak				0.15 (7)	0.18 (9)
		moderate, strong				0.2 (10)	0.25 (13)

Footnotes for Table 5-3: Wastewater Loading Rates for Residential Strength Wastewater

* Indicates soil conditions where pressure distribution systems should be used for all levels of pre-treatment (i.e., Type 1, 2 and 3).

(1) Soil characteristics are to be evaluated and described in accordance with the following recognized and established methods:

- Canadian System of Soil Classification, 3rd Edition
- CanSIS Manual for Describing Soils in the Field (Working Group on Soil Survey Data 1975)
- Book for Describing and Sampling Soils, Natural Resources Conservation Service, USDA (1998)
- Standard Practice for Subsurface Site Characterization of Test Pits for On-Site Septic Systems (ASTM, D 5921 – 96; re-approved 2003)

Soils with consistence stronger than hard (dry), firm (moist), sticky or slightly plastic (wet), or of any cemented class are considered unsuitable.

(2) Loading rates apply to the soil characteristics of the horizon in which the infiltration surface of the dispersal system will be situated as well as the characteristics of the underlying soil. It is recommended that the loading rate be based on the horizon(s) with the most limiting soil characteristics.

It is recommended that other soil characteristics, such as coarse fragments (e.g., gravel), soil color, roots, and moisture conditions be included in loading rate assessment,

Soils labeled as ‘**not recommended**’ are to be considered only when (a) an appropriate loading rate can be justified, (b) Type 2 or 3 effluent is utilized, and (c) the effluent is timed dosed using a pressure distribution system

(3) These loading rates do not apply if the soil contains greater than 40% clay and/or significant amounts of expandable clay minerals (smectite, vermiculite). In addition, advanced Type 2 effluent (< 10 mg/L BOD and TSS) or Type 3 effluent must be used.

5.7 Setback Requirements

Tables presented in this section are the minimum required standards for all sewerage systems. Deviation from the tables can only be made by a “Professional” as defined in the Regulation. All setbacks must be measured from the infiltrative surface (i.e., trench wall) to the nearest edge of the restriction (i.e., well, building)

Table 5-4: Horizontal setback distances

Distance to		From edge of distribution system ⁴ (metres/feet)				From watertight subsurface treatment tank (metres/feet)	
		Lagoon	Type 1 ¹	Type 2 ¹	Type 3 ¹		
						Septic ¹	Type 2 – 3 ¹
Property lines		15 m/ 50 ft.	3 m/ 10 ft.		1.5 m/ 5 ft.	1 m/ 3 ft.	1 m/ 3 ft.
Source of drinking water, well or water suction lines		30 m/ 100 ft. ²				15 m/ 50 ft.	15 m/ 50 ft.
Water lines (pressure)		3 m/ 10 ft.			1.5 m/ 5 ft.	1 m/ 3 ft.	1 m/ 3 ft.
Drainage or building perimeter drain	Up- gradient	3 m/ 10 ft.			1.5 m/ 5 ft.	1 m/ 3 ft.	1 m/ 3 ft.
	Down- gradient	15 m/ 50 ft.			10 m/ 33 ft.	3 m/ 10 ft.	3 m/ 10 ft.
Building non-dwelling		15 m/ 50 ft.	1.5 m/5 ft.		1 m/ 3 ft.	1 m/ 3 ft.	1 m/ 3ft.
Building dwelling		60 m/ 200 ft.	3 m/10 ft.		2 m/ 6 ft.	1 m/ 3 ft.	1 m/ 3 ft.
With basement	Up-gradient	60 m/ 200 ft.	3 m/ 10 ft.		2 m/ 6 ft.	1 m/ 3 ft.	1 m/ 3 ft.
	Down- gradient	60 m/ 200 ft	9 m/ 30 ft.		6 m/ 20 ft.	3 m/ 10 ft.	3 m/ 10 ft.
Break-out point		15 m/ 50 ft.	15 m/ 50 ft.	7.5 m/ 25 ft.	7.5 m/ 25 ft.	15 m/ 50 ft.	10 m/ 33 ft.
Utility services		1.5 m/ 5 ft.			1 m/ 3 ft.	1 m/ 3 ft.	1 m/ 3 ft.
Fresh water Marine water ³		60 m/ 200 ft.	30 m/ 100 ft.		15 m/ 50 ft.	10 m/ 33 ft.	10 m/ 33 ft.
		30 m/ 100 ft	15 m/ 50 ft.				

(1) Any reduction of horizontal setback distances must be reported to the Health Authority, verified by the site/soil evaluation report and approved by a Professional.

- (2) Any reduction of horizontal setback distances will require installation of environmental monitoring sampling wells to verify compliance with effluent quality parameters. Any setback from freshwater or source of drinking water less than 15 m/ 50 ft. requires an active local government by-law outlining monitoring and maintenance conditions.
- (3) Measured from edge of water or high tide line.
- (4) For mound systems, setback will be from the nearest edge of the required infiltrative area (i.e., trench wall).

6 PIPING

6.1 Design Considerations

Piping must be graded and sized to allow for peak hydraulic flows of sewage. Peak flows are determined by the BC Plumbing Code fixture unit method and when pipes must be drained to prevent freezing.

Gravity piping should maintain a continuous and designed grade. Pressure distribution piping should be of sufficient size to deliver the required volume and pressure.

A building sewer, an effluent sewer or a distribution header (i.e., a manifold) must be evenly and continuously supported.

6.2 Installation Standards

It might be necessary to protect building sewers or effluent sewers from freezing by a frost box, culvert or other equivalent means, particularly if there is less than 1.2 m (4') of soil cover where it crosses under a ditch, driveway or path.

Piping for effluent sewers must not have a nominal pipe size smaller than 7.5 cm (3").

A 10 cm (4") building sewer or effluent sewer must have a minimum grade of 1% ($\frac{1}{8}$ inch per foot).

A 7.5 cm (3") building sewer or effluent sewer must have a minimum grade of 2% ($\frac{1}{4}$ inch per foot).

The BC Plumbing Code specifies that:

- (1) a building sewer must not change direction or slope between the building and public sewer or between cleanouts, except that pipes not more than 6 inches in size may change direction
 - (i) by not more than 5° every 3 m, or
 - (ii) by the use of fittings with a cumulative change in direction of not more than 45° (S. 7.4.7.1), and
- (2) the size and spacing of cleanouts must conform to the following table (S. 7.4.7.2):

Table 6-1: Cleanout sizing and spacing

Size of Drainage Pipe (inches)	Minimum Size of Cleanout (inches)	Maximum Spacing (metres)	
		One Way Rodding	Two Way Rodding
< 2.5	Same size as drainage pipe	7.5	15
3 and 4	3	15	30
> 4	4	26	52

To prevent damage or dislocation of piping during and after backfill, backfill must be carefully placed and be free of stones, boulders, cinders and frozen earth.

Any plastic piping connected to a *septic tank*, *holding tank* or *packaged sewage treatment plant* must not be less in wall thickness than *DWV piping* to a point at least 1.8 m (6') from the tank.

The inlet and outlet piping connected to the septic tank are subject to distortion caused by settling of the excavation around the tank. Using heavy wall pipe and close excavation to minimize the distance to undisturbed earth provides an added element of safety.

6.3 Requirements for Materials

Every joint between pipes and fittings of dissimilar materials or sizes must be made by adapters, connectors or mechanical joints manufactured for that purpose.

The piping used for a *building sewer*, *effluent sewer*, or gravity *distribution header*, must be certified to the following standards:

- (a) CAN/CSA 8181.1 Standard for A8S Drain Waste and Vent Pipe and Pipe Fittings,
- (b) CAN/CSA 8181.2 Standard for PVC Drain Waste and Vent Pipe and Pipe Fittings,
- (c) CAN/CSA 8182.1 Standard for Plastic Drain and Sewer Pipe and Pipe Fittings, or
- (d) CAN/CSA 8182.2 Standard for PVC Sewer Pipe and Fittings (PSM Type).

Where there is no existing standard for the intended use of a piping material, piping use must comply with Table 6-2 (Piping Standards).

Table 6-2: Piping standards

Type of Piping	Standard Reference	Gravity Sewage or Effluent Piping	Pressure Effluent Line	Weeping Lateral Piping	Pressure Effluent Distribution Lateral
Polyethylene water pipe and tubing Series 160 with compression fittings Series 50, 75, 100 and 125	CAN3-B137.1-M	N	P	N	N
Poly vinyl chloride (PVC) water pipe Series 60, 100, 125, 160 and 200	CAN3-B137.3-M	P	P	P	P
Chlorinated poly vinyl chloride (CPVC) water pipe	CAN3-B137.6-M	N	N	N	P
Polybutylene water pipe	CAN3-B137.8-M	N	P	N	N
Plastic Sewer Pipe perforated non perforated	CAN/CSA-B182.1-M92	N P	N N	P N	N N
Corrugated Polyethylene perforated non perforated	CGSB 41-GP-31	N P	N N	P N	N N
Acrylonitrile- butadiene- styrene (ABS) DWV pipe	CAN/CSA-B181.1-M90	P	N	N	N
Poly (vinyl chloride) (PVC) DWV pipe	CAN/CSA-B181.2-M90	P	N	N	N
Type PSM PVC sewer pipe 35 SDR	CAN/CSA-B182.2-M90	P	N	N	N
Profile poly (vinyl chloride) (PVC) sewer pipe PS 320 kPa	CAN/CSA-B182.6-M	P	N	N	N
Profile polyethylene sewer pipe PS 320 kPa	CAN/CSA-182.6-M	P	N	N	N
Cast iron soil pipe	CAN3-B70-M	P	N	N	N

P = Permitted N = Not Permitted

7 RAW WASTEWATER CONVEYANCE

The raw wastewater ejector pump and transfer tank is used to convey raw wastewater from the facility to a septic tank where primary treatment can occur.

Authorized Persons must:

- follow BC Plumbing codes and other applicable standards for good plumbing practices.
- ensure that the pipes, pump and fittings are protected from freezing.
- equip the pump chamber with an audible high level alarm.
- ensure that electrical wiring complies with BC Electrical codes for wet and corrosive locations and be installed or inspected by a registered class C electrician or equivalent technician.
- ensure that sewage ejector transfer tank is structurally sound and watertight.
- provide adequate gas venting, either by provision of building drain and building sewer that connects to the stack vent on the building or by a separate vent.
- ensure that components are easily accessible and fitted with “quick disconnects” within 45 cm of the rim of the access riser for ease of maintenance and/or replacement. Use of cam lock type fittings is preferred over unions.

8 SEPTIC TANKS (TYPE 1) AND SEWAGE EFFLUENT TANKS

8.1 Design Considerations

8.1.1 General

The septic tank functions as a primary treatment process and, by definition, produces a Type 1 effluent.

Septic tanks shall be two compartment tanks or two tanks in series with a total working volume outlined in Table 8-1.


Septic tanks must be structurally sound, watertight and corrosion-resistant and must meet or exceed the requirements of the current CSA Standard and the standards in this manual.

The septic tank will not house any means to dose or pump effluent that causes any variation in the total working volume of the tank required in Table 8-1 (Septic Tank Volume Requirements) in Section 8.1.2. Working (or liquid) volume is measured from the inside bottom of tank to invert of outlet.

When a septic tank has an integrated pump compartment the pump compartment volume will not be calculated as part of the working volume of the septic tank.


Figure 8-1 shows a typical two compartment tank. The configuration may vary but it must meet current CSA standards.

Figure 8-1: Compartmentalized septic tank.



If the chambers are provided in individual tanks, as in Figure 8-2, the discharge from the first tank should come from an outlet baffle from about $\frac{2}{3}$ of the liquid depth from the bottom of the tank. The liquid volume of chambers in multiple tanks, single or multi-compartment, must be at least equal to the required volumes of each chamber of a two-chamber tank and sized accordingly (see Table 8-1)

Figure 8-2: Septic tank with multiple compartment provided by individual tanks.



Septic tanks must be properly fitted with a properly sized effluent filter with an effective capacity to filter particles greater than or equal to 3 mm. The effluent filter must be easily accessible for maintenance and inspection purposes. Effluent filters may also be installed in a separate chamber where installation in an existing septic tank is not practical. The effluent filter must pass a minimum flow rate 50% greater than the peak daily flow, and when 85% clogged, be able to pass a flow rate equivalent to the daily flow.

8.1.2 Septic Tank Volume Requirements

Table 8-1 shows required septic tank volume for flows up to 22,700 L/d. Calculations for table 8-1 are as follows:

For design flows of up to 9,100 litres/day, septic tanks must have a minimum working volume of three days retention time based on minimum design wastewater flow from Section 4. The minimum working volume of a tank must be 3,408 litres.

For design flows from 9,100 litres/day to 22,700 litres/day, the minimum septic tank working volume will be the amount, V, calculated by:

$$V = 15,000 + (\text{Design Flow} \times 1.34)$$

Where: V = the minimum working volume in litres; and,

Design Flow = the design flow in litres/day obtained from Section 4 of this manual.

Working (or liquid) volume is measured from the inside bottom of the tank to invert of the outlet.

Table 8-1: Septic tank volume requirementsⁱⁱⁱ

Design Daily Sewage Flow (gallons)	Design Daily Sewage Flow (litres)	Number of Bedrooms	Septic Tank working Volume (litres)	Septic Tank Working Volume (gallons)
250	1,136 or less	1 and 2 bedroom unit up to 150 m ² or 1,600 sq. ft.	3,408	750
300	1,363	3 bedroom unit up to 175 m ² 1,885 sq. ft.	4,089	900
375	1,700	4 bedroom unit up to 235 m ² 2,530 sq. ft.	5,100	1,125
450	2,045	5 bedroom unit up to 295 m ² 3,175 sq. ft.	6,135	1,350
550	2,500	6 bedroom unit up to 355 m ² 3,820 sq. ft.	7,500	1,650
660	3,000		9,000	1,980
880	4,000		12,000	2,640
1,100	5,000		15,000	3,300
1,320	6,000		18,000	3,960
1,540	7,000		21,000	4,620
1,760	8,000		24,000	5,280
1,980	9,000		27,000	5,940
2,200	10,000		28,400	6,250
2,420	11,000		29,740	6,545
2,640	12,000		31,080	6,835
2,860	13,000		32,420	7,130
3,080	14,000		33,760	7,425
3,300	15,000		35,100	7,720
3,520	16,000		36,440	8,015
3,740	17,000		37,780	8,310
3,960	18,000		39,120	8,600
4,180	19,000		40,460	8,900
4,400	20,000		41,800	9,195

4,620	21,000		43,140	9,490
4,840	22,000		44,480	9,785
	22,700		45,418	9,990

8.1.3 Watertightness Testing

All tanks should be tested for water tightness after installation where practical by filling with water (hydrostatic testing) or by vacuum testing. In both cases, the tank should be tested in the ready-to-use state. Inlets and outlets should be plumbed with the appropriate pipes, which can then be plugged for the test. Testing requirements may be found in Appendix H.

8.2 Installation Standards

8.2.1 General

Septic tanks, or sewage effluent tanks must not be located within the setback distances laid out in Section 5.7, Table 5-4.

A septic tank must have an access opening for each chamber that is level with the finished grade and have the ground graded to slope away. In areas of extreme cold climate, the riser must be insulated to prevent the tank from freezing. Access openings will be over inlet and outlet baffles or effluent filters.

To increase safety and prevent unauthorized or accidental entry into a septic tank, access openings must be equipped with a secure lid or cover. Acceptable protective lid features include but are not limited to:

- a padlock;
- a cover that can only be removed with tools; or,
- a cover having a minimum weight of 29.5 kilograms (65 pounds); and,

have beveled edges to prevent the cover from falling into the riser or tank.

An access opening extension must be water tight at the connection to the septic tank, to the sewage holding tank and at the joints between all sections.

All tanks must be manufactured with flexible watertight connectors cast-in-place. **Note: this requirement must be implemented May 2006.**

8.2.2 Installation

Authorized Persons must:

- locate all underground utilities before digging.
- ensure that all excavation, installation and backfilling work must comply with 'Workers Compensation Occupational Health and Safety Regulation' part 20.78.
- inspect tank prior to installation to ensure tank is not damaged.
- perform a watertightness test as described in Section 8.1.3.

- backfill the tank evenly on all four sides in 30 cm (12") lifts with compaction to final grade.
- ensure that manufacturers of tanks provide instructions for the handling, assembly and installation of their tanks.
- ensure that risers and lids are not shifted or distorted when backfilling.

The inlet and outlet piping connected to a tank must be protected from distortion caused by settling of the backfill material. The excavation for a tank should not be any longer than is necessary to install the tank. This provides undisturbed earth closer to the tank to support the inlet and outlet piping connected to the tank. Piping connected to the septic tank, and sewage holding tank must be supported to within 30 cm (12") of the tank on a solid base.

Pre-cast concrete tanks must not be shipped or installed until reaching design strength.

Septic Tank Abandonment^{iv}

When a septic tank is abandoned one of the following procedures must be taken in order to prevent future health and safety hazards:

- the contents of the tank are to be pumped out and the septic tank, if structurally sound, is to be filled with *inorganic* material such as soil or rock, or
- the septic tank is to be removed or broken up and the resulting excavation is to be filled with soil or rock.
- The soil absorption area can usually be left in its existing state.

9 TYPE 2 TREATMENT PLANTS

9.1 Design Considerations

Sewage that exceeds the maximum limits for residential strength sewage must not be discharged to a Type 2 treatment plant unless the plant is specifically designed for the treatment of high strength waste and the installation of the system is supervised by a Professional. Regardless of the effluent strength, all Type 2 plants must produce 45 mg/L BOD₅ 45 Total Suspended Solids prior to discharge in accordance with the Regulation.

Residential strength sewage means sewage that has a BOD₅ of less than 250 mg/L, TSS of less than 250 mg/L, and oil and grease content of less than 30 mg/L.

The minimum treatment capacity of a Type 2 treatment plant must be not less than 1,365 litres (300 gallons) per day, and not less than the design sewage flow per day.

Access openings and manhole extensions must prevent water from entering the treatment plant.

9.2 Installation Standards

A Type 2 treatment plant must not be located within the required setback distances given in Section 5.7 Table 5-4.

A Type 2 treatment plant must be provided with an access opening at or above the ground surface. The treatment plant requires regular servicing and must be readily accessible.

Access openings must be equipped with a secure lid or cover to prevent unauthorized or accidental entry into the access treatment plant. Acceptable protective measures include but are not limited to:

- a padlock;
- a cover that can only be removed with tools; or,
- a cover having a minimum weight of 29.5 kilograms (65 pounds); and,

have beveled edges to prevent the cover from falling into the riser or tank.

An access opening extension must be water tight at the connection to the Type 2 treatment plant and at the joints between all sections.

The bottom of an excavation for a Type 2 treatment plant must provide a uniform base to support the tank in a level position.

Piping connected to the Type 2 treatment plant must be supported to within 300 mm (1') from the tank on a solid base, or equivalent. The inlet and outlet piping connected to a Type 2 plant must be protected from distortion caused by settling of the backfill material. The excavation for a Type 2 plant should not be any longer than is necessary to install the plant. This provides undisturbed earth closer to the plant to support the inlet and outlet piping connected to the plant.

9.3 Requirements for Materials

A Type 2 sewage treatment plant must be:

- (a) certified by the National Sanitation Foundation as meeting the requirements of the National Sanitation Foundation (NSF) 40 Standard, for Class 1 plants, relating to Residential Wastewater Treatment Systems; or,
- (b) designed by a BC Professional Engineer and meeting the criteria of NSF 40; or,
- (c) have previously met BC Ministry of Health Services Standards for package treatment plants under Regulation 411/85.

10 TYPE 3 TREATMENT PLANTS

10.1 Design Considerations

A Professional must supervise all Type 3 design, installation and maintenance. References to Type 3 systems in this manual are intended to provide guidance for professionals but other standards may be used for Type 3 design, installation and maintenance. However, it is strongly recommended that professionals use this manual as the basis for design flows, setbacks and distribution system hydraulic loading rates.

11 EFFLUENT DISTRIBUTION

11.1 Soil Absorption Areas

The dimensions of the absorption area are critical for restricting water table mounding underneath and immediately downslope from a drainfield or sand mound. Water table mounding results when the hydraulic loading rate exceeds the horizontal flow through the soil. Saturated conditions occur and groundwater rises up to the surface. The crucial dimensions include the width, spacing and length of the trenches.

11.2 Gravity Flow Subsurface Distribution

The Authorized Person will:

- determine total daily flow rate from the facility using table 4-1 or 4-2;
- determine the distribution field size required using hydraulic loading rates table 5-3; and,
- gravity flow must not be used for distribution areas exceeding 152 lineal meters 60 cm wide trench (500 lineal feet/ 2 foot wide trench) or for distribution systems greater than 93 sq/meters (1000 sq/ft)

11.2.1 Construction Criteria

Piping will be placed in centre of trench.

Piping grade must be level or with a positive slope in the direction of flow not exceeding 5 cm in 30 m (2" in 100 ft).

Perforated pipe size not < 7.5 cm (3")

Perforations to be not < 1.27 cm (0.5")

Perforation to be begin and terminate not < 30 cm (1 ft.) from distribution manifold and trench end wall.

Perforated dispersal piping to be capped at end.

Piping to be placed in such a way as to ensure the best and most even effluent dispersal along width and length.

11.2.2 Trench Construction Criteria

Trench bottom to be level across the width and length.

Trench length must be level or with a positive slope in the direction of flow not exceeding 5 cm in 30 m (2" in 100 ft).

Trench length to be oriented parallel with contour (perpendicular to slope).

Trenches should have a long aspect ratio, long and narrow to provide equal distribution.

To have not < 15 cm (6") drain rock depth between point of discharge and trench bottom.

To have a 5 cm (2") drain rock cover above effluent dispersal pipe.

Cover drain rock with a non-biodegradable, breathable geotextile material or equivalent (i.e., building paper).

Cover trenches with not less than 15 cm (6") of soil or sod.

Trench soil backfill to be slightly crowned to allow for settling.

To be graded to provide ground water drainage away from dispersal area.

11.2.3 Effluent Infiltration Monitoring Well

Install a 10 cm diameter effluent monitoring pipe 10 cm (7.5") from the distribution pipe that has perforations beginning 5 cm (2") below the distribution pipe discharge.

11.2.4 Trench Sizing

Trench infiltrative bottom area required = Daily wastewater flow rate ÷ hydraulic loading rate (table 4-1 or 4-2 ÷ HLR table 5-3).

Total length of trenches = Trench infiltrative bottom area required ÷ the trench width.

11.2.5 Trench Dimensions

Trench width must be not less than 30 cm (1 ft.) or not greater than 90 cm (3 ft.).

Trench length to be not greater than 30 m (100 ft) for any one trench in a gravity distribution system.

Spacing must be not less than 1.8 metres (6 ft.) from centre line to centre line.

- Trenches with widths greater than 60 cm (2 ft.) spacing must be 3 times trench width.


11.2.6 Distribution Box

A distribution box, as shown in Figure 11-1, must:

- be watertight,
- be structurally sound, and provide resistant to hydrogensulphide

- provide even flow to each individual lateral by outlet levelling devices,
- be placed on a compacted and level 2.5 cm (1") sand bed, and
- provide a watertight riser access at grade to provide for maintenance

Figure 11-1: Distribution box



11.3 Aggregate (Drain Rock) Criteria

Aggregate media specifications

- Aggregate must be non-biodegradable (concrete rubble is not an acceptable aggregate)
- Effective size range from 2 cm ($\frac{1}{3}$ ") to 5 cm (2")
- All aggregate must be washed and screened and contain less than 5% fines, silt or clay coating

11.4 Construction


All work must be performed when soil moisture conditions will not adversely affect soil structure and hydraulic conductivity, the site is dry and compaction from machinery will not cause significant damage to the distribution area.

Trenches are to be constructed in a manner that does not compromise the original soil structure by smearing or compacting of soil surface.

Any smearing or compacting that does occur will need to be repaired by scarifying or tilling the surface of the distribution area.

Finished distribution area is to be graded so that rain or ground water can drain away from the site.

Seed or sod the site immediately after construction to prevent erosion.

Figure 11.2: Trench dispersal layout

For flows exceeding 9,100 litres per day:

The maximum linear hydraulic loading rate (LHLR) is required to determine the minimum total trench length. The LHLR is the rate of effluent moving into and away from the point of discharge. The minimum trench length is calculated as the design flow (as determined in Section 4) divided by the design LHLR, for which values are given in Table 10-1 (LHLR).

The Authorized Person must calculate the LHLR for all planned drainfields to confirm that the rate is less than the maximum allowable rate, or design rate, indicated in the table. At least two of the three methods of soil evaluation should be used and the most conservative, or lowest, result must be used in the calculation of trench length.

A qualified Professional may also use water table mounding calculations, full-scale mounding tests or another appropriate standard method to calculate a design linear loading rate.

Flow rates greater than 9,100 L/day require flow metres.

To Calculate LHLR use the following calculations:

Length of trench/bed = Daily wastewater flow divided by linier loading rate

Total width of trench/bed = linier loading rate divided by hydraulic loading rate

Table 11-1: Linear Loading Rates for Residential Strength Wastewater: METRIC

Soil Characteristics			Linear Loading Rates <i>gallons/ft/day (litres/m/day)</i>								
			Slope								
			0 – 4 %			5 – 9 %			> 10 %		
Texture	Structure		Depth of Natural, Unsaturated, Permeable Soil in centimetres								
	Shape	Grade	20 – 30.5	30.5 – 61	> 61	20 – 30.5	30.5 – 61	> 61	20 – 30.5	30.5 – 61	> 61
Gravelly sand		single grain	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)	4.0 (60)	4.7 (70)	5.3 (79)
Coarse to medium sand and loamy sand	—	single grain	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)	4.0 (60)	4.7 (70)	5.3 (79)
Fine sand and loamy sand	—	single grain	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
Sandy loam	massive	structureless	2.0 (30)	2.3 (34)	2.7 (40)	2.4 (36)	2.7 (40)	3.0 (45)	3.3 (49)	4.0 (60)	4.7 (70)
	platy	weak	2.0 (30)	2.3 (34)	2.7 (40)	2.4 (36)	2.7 (40)	3.0 (45)	2.7 (40)	3.3 (49)	4.0 (60)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
		moderate, strong	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
Loam	massive	structureless	1.3 (19)	1.5 (22)	1.7 (25)	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.1 (31)	2.5 (37)
	platy	weak	1.3 (19)	1.5 (22)	1.7 (25)	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.1 (31)	2.5 (37)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	2.0 (30)	2.3 (34)	2.7 (40)	2.2 (33)	2.5 (37)	2.9 (43)	2.4 (36)	2.7 (40)	3.0 (45)
		moderate, strong	2.2 (33)	2.5 (37)	2.9 (43)	2.4 (36)	2.7 (40)	3.0 (45)	2.6 (39)	2.9 (43)	3.3 (49)
Silt loam, silt	massive	structureless	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
	platy	weak	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)
		moderate, strong	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)	2.2 (33)	2.5 (37)	2.9 (43)
Clay loam, sandy clay loam, silty clay loam	massive	structureless	None	None	None	None	None	None	None	None	None
	platy	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
		moderate, strong	1.6 (24)	1.9 (28)	2.3 (34)	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)
Sandy clay, silty clay, clay	massive	structureless	None	None	None	None	None	None	None	None	None
	platy	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)

Table 11-1: Linear Loading Rates for Residential Strength Wastewater: IMPERIAL

Soil Characteristics			Linear Loading Rates <i>gallons/ft/day (litres/m/day)</i>								
			Slope								
			0 – 4 %			5 – 9 %			> 10 %		
Texture	Structure		Depth of Natural, Unsaturated, Permeable Soil in inches								
	Shape	Grade	8 – 12	12 – 24	> 24	8 – 12	12 – 24	> 24	8 – 12	12 – 24	> 24
Gravelly sand		single grain	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)	4.0 (60)	4.7 (70)	5.3 (79)
Coarse to medium sand and loamy sand	—	single grain	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)	4.0 (60)	4.7 (70)	5.3 (79)
Fine sand and loamy sand	—	single grain	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
Sandy loam	massive	structureless	2.0 (30)	2.3 (34)	2.7 (40)	2.4 (36)	2.7 (40)	3.0 (45)	3.3 (49)	4.0 (60)	4.7 (70)
	platy	weak	2.0 (30)	2.3 (34)	2.7 (40)	2.4 (36)	2.7 (40)	3.0 (45)	2.7 (40)	3.3 (49)	4.0 (60)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
		moderate, strong	2.3 (34)	3.0 (45)	3.7 (55)	2.7 (40)	3.3 (49)	4.0 (60)	3.3 (49)	4.0 (60)	4.7 (70)
Loam	massive	structureless	1.3 (19)	1.5 (22)	1.7 (25)	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.1 (31)	2.5 (37)
	platy	weak	1.3 (19)	1.5 (22)	1.7 (25)	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.1 (31)	2.5 (37)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	2.0 (30)	2.3 (34)	2.7 (40)	2.2 (33)	2.5 (37)	2.9 (43)	2.4 (36)	2.7 (40)	3.0 (45)
		moderate, strong	2.2 (33)	2.5 (37)	2.9 (43)	2.4 (36)	2.7 (40)	3.0 (45)	2.6 (39)	2.9 (43)	3.3 (49)
Silt loam, silt	massive	structureless	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
	platy	weak	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	1.6 (24)	1.8 (27)	2.0 (30)	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)
		moderate, strong	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)	2.2 (33)	2.5 (37)	2.9 (43)
Clay loam, sandy clay loam, silty clay loam	massive	structureless	None	None	None	None	None	None	None	None	None
	platy	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)
		moderate, strong	1.6 (24)	1.9 (28)	2.3 (34)	1.8 (27)	2.0 (30)	2.2 (33)	2.0 (30)	2.3 (34)	2.7 (40)
Sandy clay, silty clay, clay	massive	structureless	None	None	None	None	None	None	None	None	None
	platy	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	None	None	None	None	None	None	None	None	None
	prismatic, blocky, granular	weak	None	None	None	None	None	None	None	None	None
		moderate, strong	1.3 (19)	1.7 (22)	2.0 (30)	1.5 (22)	1.8 (27)	2.1 (31)	1.6 (24)	1.9 (28)	2.3 (34)

11.5 Pressurized Effluent Conveyance

The pressurized conveyance system relies upon pump(s), to provide even distribution of effluent to the dispersal system. The pump can be housed within:

- the third chamber of a three-chamber septic tank;
- an integrated chamber within a Type 2 or Type 3 treatment plant; and,
- a separate pump tank.

The low-pressure distribution process can control the effluent volume application rate by using either:

- an on-demand pump dosing system where pump activation will be controlled by wide angle single load rated float switch or by wide angle differential level low amp rated float switches connected to a relay housed in a watertight control box; or,
- a timed application rate pump activation will be controlled by narrow angle low amp float switches connected to a timer relay housed within a watertight control panel.

Timed application provides greater control of the dosing volume and dosing intervals.

11.5.1 Pump Tank

The pump tank will be preceded by a primary pre-treatment (septic) tank equipped with an effluent filter or another form of treatment process (Type 2 or 3) prior to discharging effluent into the pump tank.

The pump tank will be structurally sound and watertight and constructed of corrosion-resistant material such as concrete or polymer based material and must comply with current CSA standards.

The pump tank must have an access lid at surface grade level.

Access lid to be not < 60 cm (2 ft.) in diameter and ensure a watertight and gastight fit.

To increase safety and prevent unauthorized or accidental entry into a pump tank, access openings must have a secure lid or cover. Acceptable protective lid features include but are not limited to:

- a padlock;
- a cover that can only be removed with tools; or,
- a cover having a minimum weight of 29.5 kilograms (65 pounds).

and have bevelled edges to prevent the cover from falling into the riser or tank.

Polymer-based material to have a UV8 minimum protection rating.

11.5.2 Pump Tank Sizing

The type of pumping configuration that will be used determines tank sizing:

- Tank volume to provide 75% of daily flow rate above pump off level and 15% daily flow reserve volume above pump tank high level alarm's on position.
- Demand activation volume = 1 day design flow rate.

Minimum capacity 1,600 L (350 gallons).

- Timed activation volume = 2 times the daily flow.

Minimum rate capacity 3,400L (750 gallons).

This standard does not apply to pump tanks integrated into Type 2 or Type 3 treatment plants.

11.5.3 Effluent Pump

All pumps to comply with CSA and UL standards.

Be rated for the specific application.

Have non-corrosive impeller(s).

Pump inlet to be elevated at a minimum 20 cm (8") above the pump tank floor.

The elevation method must provide stable support and not obstruct the inlet.

11.5.4 Plumbing Criteria

All pipe work to follow British Columbia Plumbing Code practices

Conveyance piping materials must:

- conform with CSA standards or certified by a recognized testing agency accepted by the Standards Council of Canada, as meeting or exceed the requirements of the appropriate CSA standard for its intended use;
- have a shutoff valve on the transport pipe;
- have a check valve installed to prevent drain back of effluent between doses unless system is installed in cold climate areas as drainage of the supply pipe may be required to prevent freezing;
- be equipped with unions for quick disconnection for removal 15 cm (6") below the access lid. (Union is to be positioned at the top of the pump assembly on the pump side of the check shutoff and valve and be accessible at grade);
- be equipped with a vacuum breaker or other method to prevent siphoning of tank contents if the supply pipe is situated at a higher elevation than the effluent discharge point; and
- have a pump removal assembly. Removal assembly is to be designed to remove pump efficiently and safely and have corrosion resistant fittings.

11.5.5 Electrical Criteria

Electrical wiring must comply with BC Electrical Codes for wet and corrosive locations for all new installations. In the case of repair, wiring must be installed based on good practice.

Electrical work must be performed or inspected by a registered class C electrician or equivalent technician.

Power supply entry through riser or tank must be gastight and watertight.

Electrical connection boxes and control panel must be positioned for easy access, maintenance and adjustment requirements.

Control panel boxes to be a NEMA 4X or equivalent.

Control panel to be equipped with cycle counters and elapsed time metres.

11.5.6 Float Switch Criteria

Float switches will be mounted on a separate bracket or float tree so that they can be easily replaced and/or adjusted without removing the pump.

The float switch must be equipped with a high liquid level alarm that is both audible and visual. The alarm must be:

- placed in a conspicuous location;
- audible so as to be heard within a 30 metre (100 ft.) radius;
- wired separately from the pump; and,
- powered by a dedicated power supply.

11.5.7 Effluent Pump Filtration

Pumps must be fitted with filters to prevent field clogging. Filters must filter out particles > 2 mm ($\frac{1}{16}$ ")

11.5.8 Inspection, Monitoring and Maintenance

All monitoring, inspection and maintenance is to be performed by an Authorized Person

Inspect all electrical connections

- Ensure that high level or other alarm(s) are in working order
- Ensure that float switches are performing properly

Inspect control panel box for watertightness

- Ensure that timer or control relays are functioning


Inspect float levels

Inspect all plumbing fittings and connections

Ensure that all components are operating as per design

The pressurized conveyance system, shown in Figure 11-2, relies on pump(s), to provide even distribution of effluent to the distribution system.

Figure 11-3: Pressure distribution system



11.6 Pressure Distribution Construction

The pressure distribution network is the method that distributes effluent the most uniformly throughout the soil absorption system. It does this by using a pump or siphon to pressurize small diameter pipes with small diameter orifices that are spaced out evenly across the entire absorption system. With each pressurized dose of effluent, it is spread out evenly among all of the orifices, and therefore also to the soil.

Pressure distribution is also used in the design of mound systems.

The design of pressure distribution network systems is described in Appendix E.

11.7 Low-Pressure Effluent Distribution

The Authorized Person will:

- Determine total daily flow rate from the facility using table 4-1 or 4-2
- Determine the distribution field size required using hydraulic loading rates table 5-3
- Use pressure systems for distribution areas exceeding 152 lineal meters 60 cm wide trench (500 lineal feet/ 2 foot wide trench) or for distribution systems greater than 93 sq/meters (1000 sq/ft)
- Determine the total dynamic head pressure
- Determine the flow application rate
- Determine the distribution discharge orifice size and spacing
- Provide detailed technical and distribution system layout plans
- Perform a comprehensive test of all components and distribution pressure test to verify that the distribution system is in proper working order prior to final backfilling, grading and placing into operation

11.7.1 Design Criteria

Pre-treated to a Type 1 effluent quality with particulate filtration of not $< 2 \text{ mm } (\frac{1}{16} \text{ inch})$ prior to discharge.

Flow velocity to be not less than 60 cm (2 ft.) per second.

Residual head height variation from proximal to distal end of pipe must be not greater than 10%.

Residual head height at distribution orifice must be no less than 60 cm (2 ft.).

Orifice spacing must not be less than 60 cm (2 ft.).

Orifice diameter must not be less 5 mm ($\frac{3}{16}$ ").

Each orifice to be protected with an orifice shield:

- To be applied to both crown and invert orifice orientation to prevent excess soil erosion from effluent pressure.

Lateral spacing:

- Not less than 90 cm (3 ft.) for bed; and,
- Not less than 1.8 cm (6 ft.) for trench.

Lateral diameter not less than 3 cm (1.25") and not greater than 5 cm (2").

All laterals must be provided with an accessible cleanout access:

- Cleanout end to be equipped with a screw cap or plug fitting; and,
- Cleanout must be accessible from grade.

The last lateral orifice must be located not less than 60 cm (2 ft.) from cleanout.

The first lateral orifice must not be located less than 60 cm (2 ft.) from distribution manifold connection.

11.7.2 Orifice Orientation

Crown orifice orientation (12 o'clock) provides quickest pressurization of system.

Invert orifice orientation (6 o'clock) will require distal end air orifice at crown orientation to bleed air and prevent pump failure.

Laterals will drain in invert orientation which may be beneficial in cold climates.

11.7.3 Distribution Sizing

Sizing will be determined by:

- Daily wastewater flow rate;
- The soil effluent loading rate;
- Professional supervision of construction required when:
 - (1) slope is greater than 15%, or
 - (2) site constraints is a Class 4 on table 5-1include linear loading rate under either of these conditions; and,
- Dosing criteria.

Dosing volume to be 5 to 7 times the pipe volume of the laterals or 20% of daily flow rate but is not to exceed the daily hydraulic loading rate as determined by Table 5-3.

Residual head height at distribution orifice must be no less than 60 cm (2 ft.)

Orifice diameter must not be less 5 mm ($\frac{3}{16}$ ")

11.7.4 Pressure Test

Perform a residual head pressure test to verify proper residual head height.

Residual head height variation from proximal to distal end of pipe must be not greater than 10%.

11.7.5 Maintenance

- Periodic clean out of laterals
- Residual pressure test
- Dosing application rate and volume test

11.7.6 Cold Weather Criteria

In cold climate area, protect all piping and water filled components from freezing.

Orient laterals so that effluent drains out after the dosing period.

12 SEEPAGE BEDS

12.1.1 Site Criteria

Soil texture must be coarse sand, fine sand, loamy sand, silty sand or sandy loam.

Slope must be less than 15%. Sites not meeting this criteria require design and supervision by a Professional.

12.1.2 Construction Criteria

Pressure distribution criteria recommended for seepage beds.

Bed must be level across its width and length, be constructed perpendicular to the slope and must be as long and narrow as possible. No more than three laterals must be used.

The bed must have not less than 15 cm (6") of aggregate depth between point of discharge and bed bottom infiltration area and must have a 5 cm (2") aggregate cover above distribution pipe.

For monitoring, the bed must be equipped with a minimum of two effluent infiltration monitoring wells located at proximal and distal ends of the bottom lateral run.

The aggregate must be covered with a non-biodegradable, breathable geotextile material or equivalent (building paper) and must have a soil cover of not less than 15 cm (6").

The sites must be graded to provide drainage away from bed surface area.

Seed or sod the site immediately after construction to prevent erosion.

12.1.3 Bed Sizing

Bed infiltrative bottom area required = Daily wastewater flow rate divided by hydraulic loading rate:

Table 4-1 or 4-2 ÷ HLR Table 5-3

Infiltrative area = daily sewage flow divided by hydraulic loading rate X 1.35

Length of bed = infiltrative area divided by bed width

12.1.4 Bed Dimensions

Must be not greater than 4 metres (13 ft.) in width and 30 m (100 ft.) length.

The discharge lateral spacing must not be less than 90 cm (3 ft.) and not greater than 120 cm (4 ft.).

The beds outer edge must not be less than 45 cm from centre of discharge lateral pipe.

12.2 Aggregate (Drain Rock) Criteria

Aggregate media specifications:

- Aggregate must be non-biodegradable. (Concrete rubble is not an acceptable aggregate).
- Effective size range from 2 cm (1/3") to 5 cm (2")
- All aggregate must be washed and screened and contain less than 5% fines, silt or clay coating.

12.3 Construction


All work must be done when soil moisture conditions will not adversely affect soil structure and hydraulic conductivity, the site is dry, and compaction from machinery will not cause significant damage to the distribution area.

The bed must be constructed in a manner that does not compromise the original soil structure by smearing or compacting the soil surface.

- Any smearing or compaction that does occur will need to be repaired by scarifying or tilling the surface of the distribution area.

Finished distribution area to be graded so that rain or ground water can drain away from the site.

- Seed or sod the site immediately after construction to prevent erosion.

Figure 11-4: Bed pressure dispersal layout

13 MOUNDS

The mound is an above-grade soil absorption system used for wastewater treatment and dispersal. The mound system consists of a septic tank, a dosing chamber and the mound itself. The principal features of the mound are a gravel or aggregate layer for distribution of the wastewater, a layer of special sand imported to the site, and a layer of the native, permeable, unsaturated soil on the site.

The construction of the system depends on wastewater characteristics, siting requirements, loading rates and sizing.

The design of mound systems is described in Appendix F.

13.1 Site Criteria

The Authorized Person will:

- Determine total daily flow rate from the facility using table 4-1 or 4-2.
- Determine the distribution field size required using hydraulic loading rates Table 5-3.
- Use pressure systems for all mound distribution systems
- Determine the total dynamic head pressure
- Determine the flow application rate
- Determine the distribution discharge orifice size and spacing
- Provide detailed technical and distribution system layout plans
- Perform a comprehensive test of all components and distribution pressure test to verify that the distribution system is in proper working order prior to final backfilling, grading and placing into operation

13.2 Construction Criteria

A low-pressure distribution system must be used to disperse effluent for every mound system. See section 11 for pressure distribution criteria.

Mounds may be constructed using trench construction standards (section 10) or bed construction standards (section 12).

- Trench or bed can use aggregate, synthetic aggregate or chamber process.

Mounds must have a maximum height of 1m (3.33 ft.) with minimum vertical separation as outlined in Table 5-2, be constructed perpendicular to the slope, following contour and must be long and narrow.

The distribution basal area must be level along length and width of the mound with the berm side slope is to beginning not less than 1 metre from outer edge of distribution lateral.

Berm side slope must be greater than 3:1 horizontal to vertical ratio.

Provide for an effluent infiltrative monitoring well and a down-gradient effluent sampling monitoring well.

13.3 Fill Material Specifications

Fill material is to conform to ASTM C-33 standards and must meet the requirements of the following Table 13-1 (Mound Sand Particle Sizing Criteria).

Table 13-1: Mound sand particle sizing criteria

Sieve	Effective Particle Size	% Passing
No. 4	4.75 mm	95 – 100%
No. 8	2.36 mm	80 – 100%
No. 16	1.18 mm	50 – 85%
No. 30	0.6 mm	25 – 60%
No. 50	0.3 mm	10 – 30%
No. 100	0.15 mm	2 – 10%
No. 200	0.075 mm	< 3 %

13.4 Mound Sizing

Sizing of the mound must be determined by the hydraulic loading rates outlined in Table 5-3

13.5 Construction

All work must be done when soil moisture conditions will not adversely affect soil structure and hydraulic conductivity, the site is dry, and compaction from machinery will not cause significant damage to the distribution area.

The mound must be constructed in a manner that does not compromise the original soil structure by smearing or compacting of soil surface

- Any smearing or compacting that does occur will need to be repaired by scarifying or tilling the surface of the distribution area

Soil must be prepared by ploughing surface to a depth of not less than 15 cm (6").

Mound sand fill placement must begin shortly after basal area is prepared.

Finished distribution area must be graded so that rain or ground water can drain away from the site.

- Seed or sod the site immediately after construction to prevent erosion.

13.6 Inspection, Monitoring and Maintenance

Periodically inspect the effluent infiltration monitoring well.

Periodically sample effluent from down-gradient monitoring/sampling well.

14 GRAVELLESS AGGREGATE EFFLUENT DISPERSAL SYSTEMS

Gravelless systems or artificial aggregate systems offer alternatives to traditional pipe and gravel distribution. The use of gravelless technology has advantages in areas where aggregate is unavailable or very expensive; additionally these technologies may reduce installation costs.

14.1 Proprietary Gravelless Systems

Proprietary gravelless systems will be:

- sized according to the soil effluent loading and hydraulic loading rates (Table 5-3);
- have a load bearing capacity not less than AASHTO H-10;
- must be installed with consideration to manufacturer's instructions; and,
- chamber systems must have an effective side wall open area not less than 35% of bottom infiltrative area.

Synthetic aggregate system must:

- provide not less than the equivalent void space as a gravel aggregate system (not less than 35% void space); and,
- withstand the pressure of backfill without distortion or compaction.

15 SLOPING SITES

Sloping sites present a unique challenge for system construction. Poorly constructed or installed systems on sloping sites will be more likely to fail. The primary problem relates to the improper measurement of vertical separation and inappropriate horizontal spacing between trenches.

15.1 Slope Construction

Maintain proper unsaturated vertical separation when constructing bed or trench type dispersal systems on sloping terrain in accordance with Table 5-2.


As slope increases ensure proper spacing between trenches. Slopes greater than 15% require 3 m (10 ft.) horizontal separation between trenches.

To determine depth of trench walls on a sloped site use figure 15-1 as follows:

- Determine trench width and slope percentage across width (depth C)
- Determine depth required for aggregate, pipe and cover (depth B)
- Add depth B + depth C to get depth A

Can be applied to bed dispersal method as well (Bed slope less than 15%)

Figure 15-1: Trench depth variance on sloped site



16 LAGOONS

16.1 General

The lagoon system is a method of sewage disposal. The system consists of a septic tank and one or multiple lagoon cells. The lagoon cell itself is a large and generally rectangular excavation surrounded by a berm. The berm is made by compacting the material excavated from inside the lagoon around its outer edges. Its function is to prevent surface water from entering the cell and overloading it. There must also be a fence on top of the berm to prevent entry into the lagoon area.

Lagoons function as infiltration basins and evaporation ponds. A properly designed and sized lagoon provides enough volume to allow for the retention of effluent long enough to allow for the fluid to enter high porosity soil and enough surface area for evaporation to take place. In areas suitable for lagoons it is assumed that 60 percent of effluent is evaporated.

16.2 Siting Criteria

The Authorized Person will determine the number of test pits to be excavated. The minimum acceptable number of test pits is two soil observation test pits and three percolation or hydraulic conductivity test pits. The test pits must:

Conform to the '*Workers Compensation Act Occupational Health and Safety Regulation*', and be of a depth at least 1.0 metre (3 ft.) below the bottom of the proposed lagoon (i.e., 3.0 metres (10 ft.) deep for a 2.0 metre (6 ft.) deep lagoon).

The AP must then determine the unsaturated vertical separation, percolation or the soil hydraulic conductivity and the surface grade.

A lagoon system requires a site that has in addition to the requirements outlined in Table 5-1 and 5-3:

- A minimum area of 4.0 acres;
- A minimum unsaturated vertical depth from the bottom of the lagoon of 1 metres (3.33 feet);
- A minimum unsaturated vertical depth from the native soil surface of 3 metres (10 feet);
- A soil percolation rate of at least 60 minutes/2.5 cm (1 inch); and,

A slope no greater than 12% A lagoon system can be constructed on a site not meeting these requirements if designed and constructed under the supervision of a Professional.

Lagoons should be constructed in open areas able to take advantage of airflow to facilitate evaporation.

16.3 Construction Criteria

Septic tanks may be used as a pre-treatment for lagoons.

Effluent to the lagoon must be at least of Type 1 quality and be preceded by an appropriate septic tank. Septic tanks are used on lagoon systems to prevent solids from clogging the basal area of the lagoon reducing infiltration and to reduce fat oils and greases, which mask the lagoon surface decreasing evaporation.

For the purpose of lagoon design septic tank sizing is determined using two times daily sewage flow calculated by using Table 4-1 or 4-2. Common tank sizing is found in Table 16-1.

Table 16-1 Minimum Septic Tank Sizing for Lagoon Systems

Daily Sewage Flow Litres (gallons)	Septic Tank Sizes Litres (gallons)
1,136 L/ (250 gal)	2,272 L/ (500 gal)
1,363 L/(300 gal)	2,726 L/ (600 gal)
1,700 L/ (375 gal)	3,400 L/ (750 gal)
2,045 L/(450 gal)	4,090 L/ (900 gal)

2,500 L/ (550 gal)	5,000 L/ (1,100 gal)
--------------------	----------------------

Effluent may be discharged into the lagoon either by gravity or by pump.

All piping, and fittings must comply with Section 6, and pumps must comply with section 11 CSA and UL standards.

The piping is to be buried sufficiently to prevent freezing and be installed with “Y” style cleanout at least every 15 m (50 ft.).

16.3.1 Gravity Flow Discharge

For gravity flow discharge into the lagoon, the septic tank outlet must be higher than the top of the berm to prevent backflow. The difference in elevation between the septic tank outlet and the berm must be at least 45 cm (18").

The minimum required slopes for sewer lines are:

- 1% for a 10 cm (3") pipe and
- 2% for a 7.5 cm (2.5") pipe.

The sewer pipe must:

- extend a minimum of 2 metres (6 ft.) into the lagoon from the nearest inside wall;
- direct effluent horizontally to the centre of the lagoon; and,
- be positioned securely 30 cm (1 ft.) above the lagoon bottom.

Pipe cleanouts are required in the sewer lines and must be:

- no greater than 15 metres (50 ft.) apart;
- attached to the sewer line with a sanitary tee or “Y” with a 45° fitting;
- have cleanout caps equipped with cleanout fitting and screw type plug; and,
- cleanout caps must be accessible at the surface grade level.

16.3.2 Pumped Discharge

For discharge pumped into the lagoon, the pump must be designed to maintain a minimum flow velocity of 70 cm/second (2.5 ft/second) through the sewer pipe.

The discharge must be pumped from a separate pump tank or separate pump chamber:

The sewer pipe must:

- be fitted with a backflow prevention device that prevent sewage from entering the building;
- be positioned near the centre of the lagoon;
- be a minimum of 2 metres into the lagoon from the nearest inside wall;
- be securely anchored to the lagoon bottom; and,
- direct influent vertically to the centre of the lagoon.

16.3.3 Lagoon Sizing

The sizing of a lagoon is dependent on the water balance throughout the year of precipitation, evaporation and soil infiltration. The following minimum sizing requirements are required for lagoons in areas with positive evaporation potentials.

Lagoons must contain one year daily sewage flow and a minimum surface area to facilitate evaporation. Lagoons constructed to contain flows exceeding those outlined in tables 16-2 and 16-3 shall be sized using the following formula:

Volume of a rectangular lagoon (frustum pyramid) = $1/3h(A_1 + A_2 + \sqrt{A_1A_2})$ where h is height, A_1 is area of the top and A_2 is area of the bottom

Volume of a circular lagoon (cone) = $1/3 \text{ Pi } R^2 h$ where R is the radius and h is the height ,Pi = ~ 3.14

Surface area = 0.66 x volume in cubic meters

Volume and surface area calculator for cones and frustum pyramids may be found at:

www.webcalc.net/menu.php

Sizing criteria for lagoons are shown in Table 16-1

Table 16-2: Rectangular Lagoon cell sizing requirements

Bedrooms	Estimated Design Flow (Litres/Gallons)	Volume	Depth	Metres (feet)	Total Surface Area	
		Cubic Meters (Cubic Ft.)	Meters (feet)	Bottom Inside	Top Inside	Square metres (square feet)
1-2	1,136 L/250 gal	416 (14,951)	2 (6.5)	14 x 4m (47 x 13 ft.)	26 x 16m (87 x 53 ft.)	416 sq.m 4,611sq.ft.
3	1,363 L/300 gal	500 (18,172)	2 (6.5)	16 x 5m (53 x 17 ft.)	28 x 17m (93 x 57 ft.)	476 sq. m 5,301sq.ft.
4	1,700 L/375 gal	639 (23,168)	2 (6.5)	20 x 6m (67 x 20 ft.)	32 x 18m (107 x 60 ft.)	576 sq. m 6,420sq.ft.
5	2,045 L/450 gal	746 (26,553)	2 (6.5)	22 x 7m (73 x 23 ft.)	34 x 19m (113 x 63 ft.)	646 sq. m 7,119sq.ft.
6	2,500 L/550 gal	917 (33,128)	2 (6.5)	24 x 9m (80 x 30 ft.)	36 x 21m (120 x 70 ft.)	756 sq. m 8,400sq.ft.

Table 16-3: Circular Lagoon cell sizing requirements

Bedrooms	Estimated Design Flow (Litres/Gallons)	Volume	Depth	Diameter	Total Surface Area
		Cubic Meters (Cubic Ft.)	Meters (feet)	Metres (feet)	Square metres (square feet)
1-2	1,136 L/250 gal	506 (17,643)	4 (13)	22m (72 ft.)	380sq.m 4,090sq.ft.
3	1,363 L/300 gal	553 (19,144)	4 (13)	23m (75 ft.)	415 sq. m 5,113sq.ft.
4	1,700 L/375 gal	654 (22,884)	4 (13)	25m (82ft.)	490 sq. m 5,274sq.ft.
5	2,045 L/450 gal	763 (26,355)	4 (13)	27m (88 ft.)	572 sq. m 6,157sq.ft.
6	2,500 L/550 gal	911 (32,022)	4 (13)	29.5m (97 ft.)	683 sq. m 7,352sq.ft.

The dimensions in table 16-2 and 16-3 are based on the interior sidewalls having a horizontal slope of 2 to a vertical slope of 1. (2:1 slope).

On properties where the lagoon dimension requirements of table 16-2 or 16-3 cannot be met, variations to the dimensions may be possible provided that the total surface area and volume requirements can be met.

16.3.4 Construction

Lagoons must be oriented along the surface contours in order to reduce slope variation.

A lagoon must include the following vertical dimensions:

- have a minimum one year retention of the design sewage flow as determined by Table 4-1 or 4-2;
- the lagoon bottom is in accordance with Tables 16-2 and 16- 3 below surface level;
- the berm is 0.9 to 1.5 metres (3-5 ft.) tall;
- the allowable freeboard (height remaining between the lagoon surface and the top of the berm) is a minimum of 0.6 metres(2 ft.); and,
- the vertical separation distance, as described in Section 5.5, is of at least 1.0 metre (3 ft.). On sloped sites the berm may be constructed partially in grade; however, the berm on the lower side must not exceed 1.5 metres (5 ft.) unless the design and construction is supervised by a Professional.

The berm must be constructed so that:

- the slopes of the sidewalls are:
- 2:1 for inside walls; and,
- a minimum of 3:1 for outside walls;
- the top of the berm must be no less than 1.2 metres (4 ft.) in width when fencing is placed on the top of the berm;
- the clay soil making up the berm must be well compacted in 30 cm (1 ft.) lifts and void of all topsoils and organics.

Freezing potential is greatly reduced by the construction of an internal berm, which increases the depth of water over the pipe and insulates it. The internal berm should be:

- situated $\frac{1}{3}$ of the distance along the length of the lagoon; and,
- 1.2 metres (4 ft.) in height.

Surface drainage must be directed away from the base of the berm.

16.3.5 Fencing

A fence must be built so that:

- it completely encloses the lagoon area;
- it is 1.2 metres (4 ft.) tall; and,
- access is provided from one side.

16.4 Installation Standards

Lagoons must not be located within the setback distances laid out in Table 5-1.

16.5 Maintenance

Required maintenance of a lagoon system includes:

- maintaining the septic tank as per Section 17;
- ensuring that the effluent pump and controls are in adequate operating condition by:
- measuring the draw of the pump when engaged; and,
- checking all electrical connections;
- checking all plumbing fittings and ensure that piping is in operating condition;
- assessing structural integrity of polymer based access lids;
- maintaining fencing; and controlling vegetation growth

17 MAINTENANCE AND INSPECTION

17.1 Requirements of the Sewerage System Regulation

17.1.1 Owner

Section 10 of the Sewerage System Regulation requires that an owner ensure that a sewerage system on the owner's land is maintained in accordance with the maintenance plan provided in respect of the sewerage system.

In addition the owner must keep records of maintenance carried out according to the maintenance plan.

17.1.2 Maintenance Provider

Section 12 of the Regulation indicates that a person commits an offence if the person maintains a sewerage system without proper qualifications, i.e., without being an Authorized Person.

The Authorized Person must prepare a maintenance plan for the owner/operator.

To determine whether the maintenance plan is consistent with standard practice, the AP may have regard to the Standard Practice Manual. (Section 9).

The maintenance plan must be submitted with a letter of certification, indicating that if operated and maintained as set out in the maintenance plan, the sewerage system will not cause or contribute to a health hazard. (Section 9(1) (b)).

An Authorized Person who makes a repair or alteration to a sewerage system must provide the owner with an amendment to the maintenance plan if:

- the work is not already covered by the filing of the sewerage system with the Health Authority; and,
- the maintenance plan provided as part of the letter of certification is, if followed, no longer sufficient to ensure that the sewerage system does not cause, or contribute to, a health hazard.

17.2 Maintenance Plan

The Authorized Person must prepare the maintenance plan so that it provides the user/operator and the service person with information about the system necessary to operate and maintain it. The user/operator and the service person should be able to follow the line of reasoning used when the system was designed.

The maintenance plan must include design and measured performance data for equipment installed, timer settings, draw-down depths, litres per cm of tank and actual pump delivery (L/min). The maintenance plan must explain the assumptions made to establish the design parameters and must include the following:

- a list of system "Do's and Don'ts",

- a list of relevant contacts related to system components and ongoing operations,
- an emergency number to call, and
- a list of the responsibilities of the user/operator.

17.3 Frequency of Inspection and Maintenance

The frequency of inspection of treatment and disposal systems depends on of the level of treatment.

Septic tanks must be pumped regularly to ensure proper functioning. If the septic system is not pumped in a timely manner, solids will build up, bypass the effluent tee or baffle and clog the soil absorption system — eventually resulting in hydraulic failure (i.e., plumbing backup and wastewater appearing on the ground surface).

The following table indicates the typical frequency of pump-out based on the number of residents and the volume of the septic tank.

The table is consistent with the literature and with typical service schedules set by suppliers of Type 2 systems, establishing a level of service for certified practitioners in a competitive environment. As this applies only to new installations or repairs, local government is encouraged to establish onsite system maintenance and monitoring programs as described in “Toolkit for the Development of Management Programs for On-Site Sewage Systems”. 2003. Environment Canada Georgia Basin Ecosystem Initiative.

Table 17-1: Inspection frequencies

Component of the System	Inspection Frequency
Type 1 treatment system with gravity flow	3 years (pump out as necessary, when 60 % of liquid depth is sludge and scum. See table 17-2 below)
Type 2 and 3 treatment systems (i.e., aerobic treatment units (ATUs), intermittent sand filters, re-circulating gravel filters, attached growth systems)	3 months (pump out ATUs when 6,000 mg/L TSS in aeration tank or <10% clear zone in 30 min settling test)
Pressure distribution systems for Types 1, 2 or 3	6 months after start-up, then yearly

Table 17-2: Estimated septic tank pumping frequencies in years

Tank Volume Litres	Tank Volume (Imp. Gal.)	Household Occupancy (Number of People)						Frequency years
		2	4	6	8	10	12	
2,300	500	8.0	2.9	1.6	1.0	0.7	0.6	
2,700	600	10.5	3.7	2.1	1.3	1.0	0.7	
3,405	750	14.6	5.2	2.9	1.9	1.3	1.0	
4,100	900		6.8	3.7	2.4	1.8	1.3	
4,500	1,000		8.0	4.4	2.9	2.1	1.6	
5,000	1,100		9.2	5.0	3.3	2.4	1.8	
5,900	1,300		11.8	6.5	4.2	3.0	2.3	
6,800	1,500			8.0	5.2	3.7	2.9	
7,300	1,600			8.8	5.7	4.1	3.1	

- For year-round residences
- Based on accumulation rates from Bounds (1988)
- Entries above thick line show septic tanks that do not meet minimum septic tank volume requirements of the Standard Practice Manual assuming 2 occupants per bedroom.

17.4 Flow Trials

The flow trial is one technique that may be used to assess the capacity of a disposal system (i.e., soil absorption system). A flow trial should be carried out by a Registered Practitioner or Professional and should be preceded by a thorough inspection of the system, including the septic tank. The system should be in good working order. Further discussion on flow trials is in Appendix G.

Appendix A: Sewerage System Regulation

B.C. Reg. 326/2004
O.C. 701/2004

Deposited July 8, 2004
effective May 31, 2005

Health Act

SEWERAGE SYSTEM REGULATION

Contents

Part 1 — Definitions and General Rules

- 1 Definitions
- 2 Application
- 3 Discharge of domestic sewage

Part 2 — Holding Tanks

- 4 Permit for holding tank
- 5 Maintenance of holding tank

Part 3 — Sewerage Systems

- 6 Restriction on construction and maintenance
- 7 Authorized persons
- 8 Filing
- 9 Letter of certification
- 10 Maintenance of sewerage system

Part 4 — Enforcement

- 11 Inspections and orders
- 12 Offences

Part 1 — Definitions and General Rules

Definitions

1 In this regulation:

“**Act**” means the *Health Act*;

“**authorized person**” means a registered practitioner or a professional;

“**construct**” includes

- (a) to plan or conduct a site assessment in respect of a sewerage system,

- (b) to install, repair or alter a sewerage system, and
- (c) in the case of a professional, to supervise the doing of any matter listed in paragraphs (a) and (b);

“discharge area” means an area used to receive effluent discharged from a treatment method;

“domestic sewage” includes

- (a) human excreta, and
- (b) waterborne waste from the preparation and consumption of food and drink, dishwashing, bathing, showering, and general household cleaning and laundry, except waterborne waste from a self-service laundromat;

“effluent” means domestic sewage that has been treated by a treatment method and discharged into a discharge area;

“health authority” means the regional health board established under the *Health Authorities Act* that has jurisdiction over the geographic area in which a sewerage system is located;

“health hazard” includes

- (a) the discharge of domestic sewage or effluent into
 - (i) a source of drinking water, as defined by the *Drinking Water Protection Act*,
 - (ii) surface water,
 - (iii) tidal waters, or
 - (iv) a sewerage system that, in the opinion of an inspector, is not capable of containing or treating domestic sewage, and
- (b) the discharge of domestic sewage or effluent onto land;

“holding tank” means a watertight container for holding domestic sewage until the domestic sewage is removed for treatment;

“inspector” means a medical health officer or a public health inspector;

“maintenance”, in the case of a professional, includes to supervise the maintenance of a sewerage system;

“maintenance plan” means a set of instructions for maintaining a sewerage system that, if followed, will ensure that the sewerage system does not cause, or contribute to, a health hazard;

“owner”, in respect of land on which a sewerage system or holding tank is, or is required to be, constructed under this regulation, includes

- (a) a person registered in the land title records as the owner of the land, whether entitled to the land in the person's own right, in a representative capacity or otherwise,

- (b) a lessee or a person holding a licence to occupy the land, and
- (c) if a sewerage system or holding tank serves more than one parcel, strata lot or shared interest, the strata corporation or other corporate entity that developed the parcels, strata lot or shared interest, as applicable;

“parcel” means any lot, block or other area in which land is held or into which it is subdivided, but does not include land covered by water;

“professional” means a person who meets the requirements of section 7 (3) [*authorized persons*];

“registered practitioner” means a person who is qualified to act as a registered practitioner under section 7 (1) or (2);

“registration certificate” means a registration certificate issued by the Applied Science Technologists and Technicians of British Columbia that certifies that the holder is competent to construct and maintain a sewerage system that uses a treatment method classified as Type 1 or Type 2;

“septic tank” means a watertight container for receiving, treating and settling domestic sewage;

“sewerage system” means a system for treating domestic sewage that uses one or more treatment methods and a discharge area, but does not include a holding tank or a privy;

“shared interest” means a shared interest in land as defined in the *Real Estate Development Marketing Act*;

“standard practice” means a method of constructing and maintaining a sewerage system that will ensure that the sewerage system does not cause, or contribute to, a health hazard;

“strata lot” means a strata lot as defined in the *Strata Property Act*;

“surface water” means a natural watercourse or source of fresh water, whether usually containing water or not, and includes

- (a) a lake, river, creek, spring, ravine, stream, swamp, gulch and brook, and
- (b) a ditch into which a natural watercourse or source of fresh water has been diverted,

but does not include ground water or water in a culvert that is constructed to prevent the contamination of a watercourse by domestic sewage or effluent;

“treatment method” means a treatment method for domestic sewage classified as Type 1, Type 2 or Type 3 where

- (a) Type 1 is treatment by septic tank only,
- (b) Type 2 is treatment that produces an effluent consistently containing less than 45 mg/L of total suspended solids and having a 5 day biochemical oxygen demand of less than 45 mg/L, and

- (c) Type 3 is treatment that produces an effluent consistently containing less than 10 mg/L of total suspended solids and having
 - (i) a 5 day biochemical oxygen demand of less than 10 mg/L, and
 - (ii) a median fecal coliform density of less than 400 Colony Forming Units per 100 mL.

Application

2 This regulation applies to the construction and maintenance of

- (a) a holding tank,
- (b) a sewerage system that serves a single family residence or a duplex,
- (c) a sewerage system or combination of sewerage systems with a combined design daily domestic sewage flow of less than 22 700 litres that serves structures on a single parcel, and
- (d) a combination of sewerage systems with a combined design daily domestic sewage flow of less than 22 700 litres that serves structures on one or more parcels or strata lots or on a shared interest.

Discharge of domestic sewage

3 (1) The owner of every parcel on which a structure is constructed or located must ensure that all domestic sewage originating from the structure

- (a) is discharged into
 - (i) a public sewer,
 - (ii) a holding tank that is constructed and maintained in accordance with Part 2 [*Holding tanks*], or
 - (iii) a sewerage system that is constructed and maintained in accordance with Part 3 [*Sewerage systems*], and
 - (b) does not cause, or contribute to, a health hazard.
- (2) Despite subsection (1), a person may discharge domestic sewage or effluent into waters as described in paragraph (a) (i), (ii) and (iii) of the definition of a "health hazard" if authorized under another enactment.

Part 2 — Holding Tanks

Permit for holding tank

4 (1) A person must not construct a holding tank unless the person holds a permit issued under this section.

- (2) A person may apply for a permit to construct a holding tank by submitting to an inspector, in a form acceptable to the inspector,

- (a) information respecting
 - (i) the person's name, address and telephone number,
 - (ii) the type of structure the holding tank will serve, and
 - (iii) any other information relevant to the holding tank or structure that the inspector requires,
 - (b) a description of the holding tank, or of alterations or repairs to the holding tank,
 - (c) the proposed maintenance plan for the holding tank, and
 - (d) a permit fee of \$400.
- (3) On receiving an application under subsection (2), an inspector may
- (a) make an inspection to determine whether to issue a permit under paragraph (b), and
 - (b) issue a permit to construct a holding tank only if satisfied that
 - (i) a holding tank is adequate to deal with the domestic sewage originating from the structure, and
 - (ii) the use of the holding tank will not, if the maintenance plan is followed, cause, or contribute to, a health hazard.
- (4) An inspector may attach any conditions to a permit that are necessary for the inspector to be satisfied of the matters listed under subsection (3).
- (5) If an inspector attaches conditions to a permit, the person who constructs the holding tank must comply with those conditions.

Maintenance of holding tank

- 5 (1) An owner must ensure that a holding tank on the owner's land is maintained in accordance with the maintenance plan provided under section 4 (2) (c) [*permit for holding tank*], as modified by any conditions attached to the holding tank permit.
- (2) An owner must keep records of maintenance carried out under subsection (1).

Part 3 — Sewerage Systems

Restriction on construction and maintenance

- 6 (1) Unless qualified as an authorized person, a person must not construct or maintain a sewerage system that uses a treatment method classified as Type 1 or Type 2.
- (2) If the registration certificate of a registered practitioner contains any restrictions or conditions, a registered practitioner who constructs or maintains a sewerage system must comply with those restrictions or conditions.

- (3) Unless supervised by a professional, a person must not construct or maintain a sewerage system
 - (a) that uses a treatment method classified as Type 3, or
 - (b) designed for an estimated minimum daily domestic sewage flow of more than 9 100 litres.

Authorized persons

7 (1) A person is qualified to act as a registered practitioner if the person

- (a) has successfully completed a post-secondary training program through
 - (i) the West Coast Onsite Wastewater Training Centre, administered by the British Columbia Onsite Sewage Association, or
 - (ii) through an institution that
 - (A) is designated, registered or accredited under an enactment of Canada or any province, except British Columbia, to offer post secondary education, and
 - (B) includes, as part of its curriculum, training in soil analysis and sewerage system construction and maintenance, and
- (b) holds a registration certificate.

(2) Despite subsection (1), a person who does not meet the educational requirements of that subsection is qualified to act as a registered practitioner if the person

- (a) demonstrates to the British Columbia Onsite Sewage Association that the person is competent to construct and maintain a sewerage system that uses a treatment method classified as Type 1 or Type 2, and
- (b) holds a registration certificate.

(3) A person is qualified to act as a professional if the person

- (a) has, through education or experience, training in soil analysis and sewerage system construction and maintenance, and
- (b) is registered as a fully trained and practising member of a professional association that
 - (i) is statutorily recognized in British Columbia, and
 - (ii) has, as its mandate, the regulation of persons engaging in matters such as supervision of sewerage system construction and maintenance.

Filing

8 (1) This section does not apply to the construction of a sewerage system in respect of which information and documents have been filed under subsection (2) on a previous occasion, unless

- (a) a significant alteration or repair is being made on the sewerage system, or
 - (b) the construction of the sewerage system is in response to an order made under section 11 (1) (b) (ii), (iii) or (iv) [*inspections and orders*].
- (2) Before construction of a sewerage system, an authorized person must file with the health authority, in a form acceptable to the health authority,
- (a) information respecting
 - (i) the name, address and telephone number of the owner for whom the sewerage system is being constructed,
 - (ii) the type of structure the sewerage system will serve, and
 - (iii) the type, depth and porosity of the soil at the site of the sewerage system,
 - (b) plans and specifications of the sewerage system, or of alterations or repairs to the sewerage system, prepared by an authorized person and with the seal of the authorized person affixed,
 - (c) written assurance that the plans and specifications filed under paragraph (b) are consistent with standard practice, and
 - (d) if construction of the sewerage system is in response to an order made under section 11 (1) (b) (ii), (iii) or (iv), a copy of the order.
- (3) To determine whether the plans and specifications filed under subsection (2) (b) are consistent with standard practice, an authorized person may have regard to the Ministry of Health Services' publication "Sewerage System Standard Practice Manual" as amended from time to time.
- (4) If there is a material change in the information filed under subsection (2) before the authorized person provides a letter of certification under section 9 (1) (b) [*letter of certification*], the authorized person must promptly file an amendment with the health authority.

Letter of certification

9 (1) Within 30 days of completing the construction of a sewerage system to which section 8 [*filing*] applies, an authorized person must

- (a) provide the owner with
 - (i) a copy of the sewerage system plans and specifications as provided to the health authority under section 8 (2) (b),
 - (ii) a maintenance plan for the sewerage system that is consistent with standard practice, and
 - (iii) a copy of the letter of certification provided to the health authority under paragraph (b),

- (b) file with the health authority a signed letter certifying that
 - (i) the authorized person has complied with the requirements of paragraph (a),
 - (ii) the sewerage system has been constructed in accordance with standard practice,
 - (iii) the sewerage system has been constructed substantially in accordance with the plans and specifications filed under section 8 (2) (b),
 - (iv) for a sewerage system described in section 2 (c) or (d) *[application]*, the estimated daily domestic sewage flow through the sewerage system will be less than 22 700 litres, and
 - (v) if operated and maintained as set out in the maintenance plan, the sewerage system will not cause or contribute to a health hazard, and
- (c) append to the letter required under paragraph (b)
 - (i) a plan of the sewerage system as it was built, and
 - (ii) a copy of the maintenance plan for the sewerage system.
- (2) To determine whether sewerage system construction and a maintenance plan in respect of the sewerage system are consistent with standard practice, an authorized person may have regard to the Ministry of Health Services' publication "Sewerage System Standard Practice Manual", as amended from time to time.
- (3) If an authorized person does not file a letter of certification under subsection (1) (b) within one year from filing information about the sewerage system under section 8, the authorized person must not begin or continue construction of the sewerage system until the authorized person files new information under section 8.

Maintenance of sewerage system

- 10** (1) An owner must ensure that a sewerage system on the owner's land is maintained in accordance with the maintenance plan provided in respect of the sewerage system.
- (2) An owner must keep records of maintenance carried out under subsection (1).
 - (3) An authorized person who makes a repair or alteration to a sewerage system must provide the owner with an amendment to the maintenance plan if
 - (a) section 8 *[filing]* does not apply to the repair or alteration, and
 - (b) the maintenance plan previously provided under section 9 (1) (a) (ii) *[letter of certification]* is, if followed, no longer sufficient to ensure that the sewerage system does not cause, or contribute to, a health hazard.

Part 4 — Enforcement

Inspections and orders

- 11** For the purpose of determining whether a holding tank or sewerage system is the cause of, or may be contributing to, a health hazard, an inspector may
- (a) inspect, in accordance with section 61 [*inspection authority*] of the Act,
 - (i) the parcel on which the holding tank or sewerage system is located, and
 - (ii) any parcels that may be affected by the health hazard, and
 - (b) order an owner, in accordance with section 63 [*order*] of the Act, to do one or more of the following:
 - (i) connect a structure to a public sewer;
 - (ii) connect a structure to, in the inspector's discretion, a holding tank or sewerage system;
 - (iii) alter or repair a holding tank or sewerage system;
 - (iv) take any other action necessary to remedy the health hazard.

Offences

- 12** A person commits an offence if the person
- (a) knowingly makes a false or misleading statement
 - (i) in the information submitted or filed under section 4 [*permit for holding tank*] or 8 [*filing*],
 - (ii) in providing the information required under section 9 [*letter of certification*], or
 - (iii) during an inspection under section 11 (a) [*inspections and orders*],
 - (b) constructs or maintains a sewerage system without proper qualifications, as set out in section 6 [*restriction on construction and maintenance*],
 - (c) constructs a holding tank or sewerage system, or fails to repair or maintain a holding tank or sewerage system, in a manner that causes or contributes to a health hazard,
 - (d) fails to comply with
 - (i) a requirement to file any of the matters described in section 8,
 - (ii) a requirement to provide information or a letter of certification under section 9, or
 - (iii) an order under section 11 (b), or
 - (e) operates
 - (i) a holding tank for which no permit has been issued under section 4, or
 - (ii) a sewerage system for which no letter of certification has been filed under section 9.

Note: this regulation replaces B.C. Reg. 411/85.

[Provisions of the *Health Act*, R.S.B.C. 1996, c. 179, relevant to the enactment of this regulation: section 8]

Appendix B: Procedure for Percolation Test

PROCEDURE FOR PERCOLATION TEST

The percolation test is to be conducted as follows in order to determine the suitability of the soil to absorb effluent:

- (1) percolation test holes must be made at points and elevations selected as typical in the area of the proposed absorption field;
- (2) test holes must be dug at each end of the area of the absorption field. Further holes may be required, depending upon the nature of the soil, the results of the first tests and the size of the proposed absorption field;
- (3) test holes must be 30 cm (12 in.) square and excavated to the proposed depth of the absorption field;
- (4) to make the percolation test more accurate, any smeared soil should be removed from the walls of the test holes;
- (5) if the soil contains considerable amounts of silt or clay, the test holes must be pre-soaked before proceeding with the test. Pre-soaking is accomplished by keeping the hole filled with water for 4 hours or more. The test must be carried out immediately after pre-soaking;
- (6) to undertake the test, fill the test hole with water. When the water level is 13 cm (5 in.) or less from the bottom of the hole, refill the hole to the top. No recording of time needs be done for these 2 fillings;
- (7) when the water level, after the second filling (procedure (6)) is 13 cm (5 in.) or less from the bottom of the hole, add enough water to bring the depth of water to 15 cm (6 in.) or more;
- (8) observe the water level until it drops to the 15 cm (6 in.) depth, at precisely 15 cm (6 in.), commence timing, when the water level reaches the 12.5 cm (5 in.) depth, stop timing, record the time in minutes;
- (9) repeat procedures (7) and (8) until the last 2 rates of fall do not vary more than 2 minutes per 2.5 cm (per inch);
- (10) determine the percolation rate for the proposed sewage disposal system by averaging the slowest rate determined for each of the test holes;

(11) backfill the holes with the excavated soil and flag their locations.

Appendix C: Recommendation for Field Tests of Soil Permeability

SOIL HYDRAULIC CONDUCTIVITY

This Appendix is a recommended guide for field tests of soil permeability, including percolation tests and the constant-head borehole permeameter.

Field tests of soil hydraulic conductivity, or permeability, must be conducted in the planned drainfield area, in unsaturated native soils, at the depth of the planned infiltration surface. A variety of test methods may be used, including the constant-head borehole permeameter (Pask or Guelph Permeameter), double ring infiltrometer, and trench pump-in test. These tests estimate the soil's saturated hydraulic conductivity (K_{sat}) by temporarily saturating a zone or bulb of soil within the unsaturated zone. The calculated hydraulic conductivity is therefore referred to as the field-saturated soil hydraulic conductivity (K_f s), which will be less than K_{sat} .

When using test results from a constant-head borehole permeameter, the K_{sat} may be estimated as $2.0 \times K_f$ s (Gupta et al, 1994).

The K_f s value that is used to calculate HLR should normally be based on at least four field tests, and the K_f s value used should be the second lowest value measured. For example, consider the following four test results for K_f s using a constant-head borehole permeameter: (1) 36 cm/day; (2) 47 cm/day; (3) 78 cm/day; (4) 19 cm/day. The design K_f s used should be no more than the second lowest value, 36 cm/day.

Using the same example, and assuming a Type 1 system with a design K_f s of 25 to 50 cm/day, the design HLR would be 24 Lpd/m².

If six or more tests are conducted, the third lowest K_f s value may be used as the representative value.

PERCOLATION TESTS

Similarly, when using percolation tests, a minimum of four tests must be conducted, and the value used for selecting a soil hydraulic loading rate must be the second slowest percolation rate.

This simple protocol follows the widely recommended approach of using a design value that is no higher than the median, but higher than the worst-case measurement, which is not normally representative. A Professional may use a different protocol than that outlined above, provided the reasoning is documented.

In all cases, the planner or Professional that tests the soil permeability must document the type of test, the standard method used, the location and depth of each test, the complete test results, and the calculations of soil hydraulic conductivity. In most cases, this information can be recorded on a standard field form.

Appendix D: Calculating Design HLR from Soil Hydraulic Conductivity

INTRODUCTION

This appendix provides the technical grounding for Method (3), in which a design soil HLR may be selected by conducting hydraulic conductivity tests at the location and depth of the planned infiltration surface. The simplest approach for using results from these tests, for moderately permeable soils, is to calculate HLR by multiplying the soil's saturated hydraulic conductivity (K_{sat}) by a factor, commonly 1% to 4% for Type 1 effluent (Crites et al, 2000; Lesikar et al, 1998; Siegrist et al, 2004; US EPA, 1992; WEF, 1990). In general, tests of hydraulic conductivity conducted in unsaturated soil will measure the field-saturated hydraulic conductivity (K_f). K_{sat} is commonly about $2.0 \times K_f$ (Gupta et al, 1994), so this would indicate an HLR calculated as 2% to 8% of K_f .

For simplicity, this method calculates a soil HLR based on the field saturated hydraulic conductivity (K_f), although many manuals and papers recommend calculating HLR from the saturated hydraulic conductivity (K_{sat}). We recommend this approach because tests conducted in the unsaturated zone will directly measure K_f , and it is simpler to calculate the HLR directly from the K_f .

The approach recommended for Method (3), is based on an integration of recommendations in several design manuals and research papers, primarily Jenssen and Siegrist (1991), Taylor et al (1997), Smith (2000), Crites et al (2000), Winneberger (1985), and Kilduff (1989).

DRAINFIELDS

Use the following Table D:1 (Method 3) for calculating a design soil HLR for a drainfield, using the soil's field-saturated hydraulic conductivity (K_f), and the effluent type.

Alternative to Table D-1: Method 3

Instead of using Table D-1, a Professional may use the following equations, where K_{sat} is in cm/day, $K_{sat} = 2.0 \times K_f$, and HLR is in Lpd/sqm (based on Taylor et al, 1997):

$$\text{Type 1: } HLR = 9 \times K_{sat}^{0.25} \{\text{limited to a maximum HLR of } 0.1 \times K_{sat}, \text{ in mm/day}\}$$

$$\text{Type 2: } HLR = 18 \times K_{sat}^{0.25} \{\text{limited to a maximum HLR of } 0.2 \times K_{sat}, \text{ in mm/day}\}$$

$$\text{Type 3: } HLR = 36 \times K_{sat}^{0.25} \{\text{limited to a maximum HLR of } 0.3 \times K_{sat}, \text{ in mm/day}\}$$

Table D-1: Method 3 — Calculating design soil hydraulic loading rate (HLR) for a drainfield from the soil's field saturated hydraulic conductivity

Field – Saturated Hydraulic Conductivity (Kfs)		Design Soil HLR (Lpd/m ²)			Typical soil texture and structure *	Typical Perc Rate * (min/ inch)
cm/d	mm/d	Type 1	Type 2	Type 3		
> 200**	> 2,000	40	80	161	Gravelly to very gravelly sand (single grain)**	< 1**
100	1,000	34	68	135	Sand (single grain) or gravelly sand (massive)	1 – 3
50	500	28	57	114	Loamy sand (single grain) or sand (massive)	3 – 9
25	250	24	48	96	Well structured sandy loam or silt. Massive loamy sand.	5 – 15
12.5	125	20	40	75	Well structured loam or silt loam. Poorly structured sandy loam or silt.	10 – 25
6	60	12	24	36	Well structured silty clay loam. Poorly structured loam or silt loam.	15 – 30
3	30	6	12	18	Well structured sandy clay loam or clay loam. Poorly structured silty clay loam.	25 – 60
1.5**	15	0	6	9	Well structured sandy clay, silty clay, or clay. Poorly structured sandy clay loam or clay loam.**	30 – 90**
0.5**	5	0	0	3	Poorly structured sandy clay or silty clay.**	60 – 180**
< 0.5**	< 5	0	0	0	Poorly structured clay.**	> 90**

* Typical soil texture, structure, and percolation rate are provided here for comparison purposes.

** Indicates site conditions for which pressure distribution should be required.

Discussion of Table D-1

The relationship between soil hydraulic conductivity and percolation rate is based on Winneberger (1985). The relationship between soil hydraulic conductivity and soil texture is based on Saxton et al (1985).

Appendix E: Pressure Distribution Network Design

The pressure distribution network is the method that distributes effluent the most uniformly throughout the soil absorption system. It distributed effluent by using a pump or siphon to pressurize small diameter pipes with small diameter orifices that are spaced out evenly across the entire absorption system. With each pressurized dose of effluent, effluent is spread out evenly to all of the orifices, and therefore also to the soil.

The design of a pressure distribution system is broken into two parts. The first part is the design of the distribution network itself and the second part is the design of all of the other components such as the force main, dosing chamber, pressurization unit and controls. The procedures follow.

1 DISTRIBUTION NETWORK DESIGN

1.1 Soil Absorption System Size and Configuration

The first step in designing the distribution network is to determine the size and configuration of the soil absorption system. Determine the area of the distribution system based on the soil characteristics, the design and average flows.

1.2 Lateral Length

The next step is to determine the lengths of laterals. This will depend on whether the manifold will be centre or end feeding and how evenly the effluent will disperse. The proximal discharge rate (the discharge rate at the nearest orifice to the manifold) must be no more than 10% greater than the distal discharge rate within a lateral or there must be no difference of greater than 15% in discharge rates through the entire network. The change in discharge rates among orifices depends on the lateral length and determines the maximum lateral length.

Centre Manifold

The lateral length will be roughly half of the length of the distribution field,. The ends of the laterals must be within 15 to 30 cm of the end of the absorption field. The lateral length is calculated as the length of the absorption field divided by two less 15 cm.

End Manifold

The lateral length will be roughly the length of the entire field. The ends of the laterals must be within 15 to 30 cm of the end of the absorption field. The lateral length is calculated as the length of the absorption field less 30 cm.

1.3 Orifice Size, Spacing and Position

The third step is to determine the size, spacing and position of the orifices, or perforations. The combination of these parameters must be appropriate for the design flow of the distribution network. Sizes of the orifices also determine how evenly the effluent will be distributed.

The size of the orifices can vary from 6.35 mm (¼") to 3.18 mm (⅛") in diameter. Quarter inch diameter orifices are the most typical, but as effluent filters in septic tanks become more common and remove larger particles, smaller orifices can be used. Also, more energy and greater flows are required in order to maintain pressure for larger orifices. There are also concerns regarding clogging with the smaller diameter perforations of 3.18 mm (⅛") when they are placed downwards and have been drilled on-site instead of under the controlled conditions of a shop. A midrange diameter of 4.76 mm (⅜") is a satisfactory compromise to achieve the advantages of both sizes.

Orifice spacing must be as even as possible so that treatment efficiency is maximized. It has typically been recommended that orifices be spaced every 30 to 36 inches, but this can vary with the system still functioning efficiently. It is now more commonly recommended that there be 0.56 m² (6 square feet) of the soil absorption field per orifice.

$$\text{Orifice spacing} = \frac{0.56 \text{ m}^2 (6 \text{ sq. ft.)} \times \text{the number of laterals located side by side}}{\div \text{the width of the soil absorption field.}}$$

If there is an option regarding how many laterals will be located side by side, then it is preferable that the option that results in the squarest area of the soil absorption system per orifice be selected.

Positioning of the orifices on the laterals can depend on the site and the length of the laterals. Orifices can either be placed on the tops of the laterals with an orifice shield or they can be placed downwards on the bottoms of the laterals. Other methods of shielding the upward facing orifices are placing a 7.6 or 10 cm (3 or 4") diameter half pipe over the length of the lateral or by placing a full 10 cm (4") diameter pipe with orifices in it around the entire lateral. It is important in cold climates that the system drain after each dosing to avoid freezing. This can be achieved by having those laterals with the orifices placed upward sloped back towards the pressure main or by having the orifices located downward. Longer laterals will be more difficult to angle than will short ones.

1.4 Lateral Pipe Diameter

Choose the diameter and class of the lateral pipes by using Table E-1 and the information gathered in Sections 1.2 and 1.3 (lateral length and orifice diameter and spacing).

1.5 Number of Perforations Per Lateral

Determine the number of perforations on each lateral by using the lateral length, the perforation spacing and whether the system uses a centre or end manifold.

*(The number of perforation per lateral = the lateral length ÷ the orifice spacing) + 0.5
for a lateral manifold OR + 1.0 for an end manifold.*

The result should be rounded to the nearest whole number.

1.6 Lateral Discharge Rate

The orifice discharge rate can be found in Table E-2 and is multiplied by the number of orifices per lateral to find the lateral discharge rate. Use the table if the values of the residual pressure head at the orifices and the diameter of the orifices are known. These values as well as those not found in the table can also be found using the equation:

$$Q = 11.79 d^2 \sqrt{h}$$

Where: Q = the orifice discharge rate in US gallons per minute

d = the orifice diameter in inches

h = residual pressure head at the orifice in feet

Another method is to use recommended residual pressure heads depending on the orifice diameter. The recommended pressures are 0.76 m (2.5 ft) for a 6.35 mm ($\frac{1}{4}$ ") orifice, 1.07 m (3.5 ft) for a 4.76 mm ($\frac{3}{16}$ ") orifice and 1.52 m (5 ft) for a 3.18 mm ($\frac{1}{8}$ ") orifice.

$Q \times \text{the number of orifices on a lateral} = \text{the lateral discharge rate in US gpm.}$

1.7 Number of Laterals and Spacing Between Laterals

The number of laterals was probably determined at the same time as the orifice spacing in Section 1.3. The two are closely related since they both must be considered to meet the criteria of having 6 square feet of absorption area per orifice in the squarest dimensions possible. The number of laterals located side by side in the absorption area should reflect the layout that provides these square dimensions. The number of laterals refers to the number of laterals located side by side for end manifolds, or this number multiplied by two for centre manifolds. The spacing between the laterals can be calculated by dividing the width of the soil absorption system by the number of side-by-side laterals.

1.8 Manifold Size and Length

The length of the manifold is the distance between the outermost laterals. If the system is only one lateral wide then there is no manifold. The size, or diameter, of the manifold pipe for small systems must be the same size as the force main and can be determined using either Table E-3a or Table E-3b, depending on the orifice diameters. These tables are used knowing the length of the manifold, whether it is a centre or end manifold and the lateral discharge rate and spacing. The values in the tables do not increase consistently from left to right due to the increase in laterals served by a given manifold length.

1.9 Network Discharge Rate

The network discharge rate can be calculated using either the perforation or lateral discharge rates. The perforation discharge rate must be multiplied by the number of perforations in the entire system, while the lateral discharge rate must be multiplied by the number of laterals. Use the resulting network discharge rate when sizing the pump or siphon in Section 2 because the pressurization unit must discharge at least this rate.

1.10 Provision for Flushing of Laterals

The distribution network must be designed in such a way that allows for periodic flushing of the laterals. This can be accomplished by providing easy access to laterals such as turn-ups, where the ends of the laterals are turned upwards and can be accessed from the surface.

2 FORCE MAIN, DOSING CHAMBER, PRESSURIZATION UNIT AND CONTROLS

2.1 System Performance Curve

A system performance curve must be plotted that illustrates total flow in gallons per minute on the x-axis versus total head in feet on the y-axis. The curve predicts the performance of the system under different pressure heads and flow rates. Plotting the curve is a multi-stepped procedure beginning with the selection of five flow rates both above and below the network discharge rate found in Section 1.9. For each of these flow rates, the total pressure head needs to be calculated, which is the sum of the elevation head, the force main head and the network head.

2.1.1 Elevation Head

The elevation head is the height that the effluent must be raised between the pressurization unit and the highest point in the distribution network. This will be the same for each flow rate.

2.1.2 Force Main Head

The force main head is the loss in head due to the friction within the force main and will be different for each flow rate. This can be calculated using the following formula:

$$f = L (Q \div K)^{1.85}$$

Where: f = friction loss in feet
 L = length of force main in feet
 Q = flow in gallons per minute
 K = constant

The value of K can be found in Table E-4 and depends on the diameter and class of the pressure main pipe. Pipefittings also affect head loss due to friction. The effect can be determined by using Table E-5, which gives the equivalent length of pipe for various types of fittings and pipe sizes.

2.1.3 Network Head

The network head is the head required by the distribution network with consideration given to the head loss due to friction. It will vary depending on the flow rate and can be calculated by:

$$H = 1.3 (Q \div (11.79 d^2))^2$$

Where: H = head in feet

Q = orifice flow rate in gallons per minute

d = orifice diameter in inches

The orifice flow rate can be calculated by dividing the selected flow rates by the number of orifices in the distribution network. The orifice diameter was determined in Section 1.3. The multiplier of 1.3 is the adjustment for friction loss in the laterals and manifold and assumes correct sizing of these pipes.

The addition of the results from (a) through (c) gives the total pressure head for each flow rate. These can then be plotted to create the system performance curve.

2.2 Force Main Diameter

The force main must be the same diameter as the manifold for smaller systems, as determined in Section 1.8.

2.3 Pressurization Unit Selection

The pressurization unit can be either a pump or a syphon.

2.3.1 Pumps

A pump is best selected by evaluating the system performance curve simultaneously with the performance curve of various pumps. A pump must be selected that will be able to produce the required flow rate at the correct head. Mark the system performance curve at the point with the correct flow rate and select the pump whose performance curve next crosses the curve above the marked flow rate. Any pump whose performance curve crosses the system performance curve above the correct flow rate could be used; however, oversized pumps are more costly. A pump should never be undersized.

There are two types of pumps that can be used to pressurize the network: the centrifugal effluent pump and the turbine effluent pump. The centrifugal pump has relatively high capacity and produces a lower head, while the turbine pump has a relatively low capacity but produces a higher head. The use of turbine pumps in onsite systems is relatively

recent and the fact that they tend to have longer lifetimes makes them the favoured choice.

2.3.2 Siphons

Siphons must be correctly sized so that the system discharge rate from the perforations is greater than the siphon flow rate. If this criterion is not met then the distal pressure will be too low and distribution will not be even. The head is achieved by having effluent back up in the pipes.

2.4 Required Dose Volume

Setting the appropriate dose flow is essential to achieving even distribution. The required volume per dose should be 5 times the volume in the lateral pipes and each dose should not be greater than 20% of the daily design flow. Table E-6 gives the volume within a foot of lateral piping based on the pipe diameter and class. The volume per length of pipe should be multiplied by the total length of laterals within the distribution system and then by five to achieve the dose volume. The dose volume also includes the flow back per dose. The flow back is the volume within the force main. To calculate the flow back the force main length is multiplied by the volume per length of the force main found in Table E-6.

2.5 Dose Chamber Size

The dose chamber must provide adequate volume for all of the following: the dose volume, the dead space due to the concrete block on top of which the pump is placed, head space for floats and a reserve volume of 100 gallons per bedroom. Dead space also results when turbine pumps are used since they are relatively tall and must be completely submerged. For timed dosing, additional volume also needs to be provided for surge storage. One method recommends adding a surge capacity of another $\frac{2}{3}$ of the daily design flow volume.

2.6 Control and Alarm Selection

Quality alarms and controls should be selected that follow appropriate electrical codes. There are control systems for both demand and timed dosing. For demand dosing, controls consist of an on-off float switch and an alarm float, while for timed dosing, controls consist of a timed on-off switch and an alarm float. Timed dosing has the advantage of providing more frequent doses and evening-out peak flows.

Table E-1: Lateral design table

			Maximum Lateral Length (ft)		
Orifice	Lateral	Orifice Spacing	Pipe Material		
(inches)	(inches)	(feet)	Schedule 40	Class 200	Class 160
1/8	1	1.5	42	51	
1/8	1	2	50	62	
1/8	1	2.5	57.5	72.5	
1/8	1	3	66	81	
1/8	1	4	80	96	
1/8	1	5	90	110	
1/8	1	6	102	126	
1/8	1.25	1.5	66	76.5	79.5
1/8	1.25	2	80	92	96
1/8	1.25	2.5	92.5	107.5	110
1/8	1.25	3	105	120	123
1/8	1.25	4	124	144	148
1/8	1.25	5	145	165	175
1/8	1.25	6	162	186	192
1/8	1.5	1.5	85.5	96	100.5
1/8	1.5	2	104	116	120
1/8	1.5	2.5	120	135	140
1/8	1.5	3	135	150	156
1/8	1.5	4	164	184	188
1/8	1.5	5	190	210	220
1/8	1.5	6	210	240	246
1/8	2	1.5	132	141	145.5
1/8	2	2	160	170	176
1/8	2	2.5	185	197.5	202.5
1/8	2	3	207	222	228
1/8	2	4	248	268	276
1/8	2	5	290	310	320
1/8	2	6	324	348	360
5/32	1	1.5	31.5	39	39
5/32	1	2	36	46	46
5/32	1	2.5	42.5	52.5	52.5
5/32	1	3	48	60	60
5/32	1	4	56	72	72
5/32	1	5	65	80	85
5/32	1	6	72	90	96
5/32	1 1/4	1.5	48	55.5	58.5
5/32	1 1/4	2	58	68	70
5/32	1 1/4	2.5	67.5	77.5	80
5/32	1 1/4	3	75	87	90
5/32	1 1/4	4	92	104	108
5/32	1 1/4	5	105	120	125
5/32	1 1/4	6	120	138	144

Source: Washington State Department of Health, 2001

			Maximum Lateral Length (ft)		
Orifice	Lateral	Orifice Spacing	Pipe Material		
(inches)	(inches)	(feet)	Schedule 40	Class 200	Class 160
5/32	1 1/2	1.5	63	70.5	73.5
5/32	1 1/2	2	76	84	88
5/32	1 1/2	2.5	87.5	97.5	102.5
5/32	1 1/2	3	99	111	114
5/32	1 1/2	4	120	132	136
5/32	1 1/2	5	140	155	160
5/32	1 1/2	6	156	174	180
5/32	2	1.5	96	103.5	106.5
5/32	2	2	116	124	128
5/32	2	2.5	135	142.5	147.5
5/32	2	3	150	162	168
5/32	2	4	184	196	200
5/32	2	5	210	225	235
5/32	2	6	240	252	264
3/16	1	1.5	24	30	
3/16	1	2	28	36	
3/16	1	2.5	32.5	42.5	
3/16	1	3	39	45	
3/16	1	4	44	56	
3/16	1	5	50	65	
3/16	1	6	60	72	
3/16	1.25	1.5	37.5	43.5	45
3/16	1.25	2	46	54	56
3/16	1.25	2.5	52.5	62.5	62.5
3/16	1.25	3	60	69	72
3/16	1.25	4	72	84	88
3/16	1.25	5	85	95	100
3/16	1.25	6	96	108	114
3/16	1.5	1.5	49.5	55.5	57
3/16	1.5	2	60	68	70
3/16	1.5	2.5	70	77.5	80
3/16	1.5	3	78	87	90
3/16	1.5	4	92	104	108
3/16	1.5	5	110	120	125
3/16	1.5	6	120	138	144
3/16	2	1.5	76.5	81	84
3/16	2	2	92	98	102
3/16	2	2.5	105	112.5	117.5
3/16	2	3	120	129	132
3/16	2	4	144	152	160
3/16	2	5	165	180	185
3/16	2	6	186	198	210
7/32	1	1.5	19.5	24	
7/32	1	2	24	30	

			Maximum Lateral Length (ft)		
Orifice Diameter	Lateral Diameter	Orifice Spacing	Pipe Material		
(inches)	(inches)	(feet)	Schedule 40	Class 200	Class 160
7/32	1	2.5	27.5	35	
7/32	1	3	30	39	
7/32	1	4	36	44	
7/32	1	5	45	55	
7/32	1	6	48	60	
7/32	1.25	1.5	31.5	36	37.5
7/32	1.25	2	38	44	46
7/32	1.25	2.5	42.5	50	52.5
7/32	1.25	3	48	57	60
7/32	1.25	4	60	68	72
7/32	1.25	5	70	80	80
7/32	1.25	6	78	90	90
7/32	1.5	1.5	40.5	45	46.5
7/32	1.5	2	50	54	56
7/32	1.5	2.5	57.5	62.5	65
7/32	1.5	3	63	72	75
7/32	1.5	4	76	88	88
7/32	1.5	5	90	100	105
7/32	1.5	6	102	114	114
7/32	2	1.5	63	66	69
7/32	2	2	76	80	84
7/32	2	2.5	87.5	92.5	95
7/32	2	3	99	105	108
7/32	2	4	116	124	132
7/32	2	5	135	145	150
7/32	2	6	156	162	168
1/4	1	1.5	16.5	21	
1/4	1	2	20	24	
1/4	1	2.5	22.5	27.5	
1/4	1	3	27	33	
1/4	1	4	32	40	
1/4	1	5	35	45	
1/4	1	6	42	48	
1/4	1.25	1.5	27	30	31.5
1/4	1.25	2	32	36	38
1/4	1.25	2.5	37.5	42.5	45
1/4	1.25	3	42	48	48
1/4	1.25	4	48	56	60
1/4	1.25	5	55	65	70
1/4	1.25	6	66	72	78
1/4	1.5	1.5	34.5	39	39
1/4	1.5	2	42	46	48
1/4	1.5	2.5	47.5	52.5	55
1/4	1.5	3	54	60	63

			Maximum Lateral Length (ft)		
Orifice	Lateral	Orifice Spacing	Pipe Material		
(inches)	(inches)	(feet)	Schedule 40	Class 200	Class 160
1/4	1.5	4	64	72	76
1/4	1.5	5	75	85	85
1/4	1.5	6	84	96	96
1/4	2	1.5	52.5	55.5	58.5
1/4	2	2	64	68	70
1/4	2	2.5	72.5	77.5	80
1/4	2	3	81	87	90
1/4	2	4	100	104	108
1/4	2	5	115	120	125
1/4	2	6	126	138	144

Table E-2: Orifice discharge rates in gallons per minute (gpm)

Head (feet)	Orifice Diameter (inches)				
	1/8	5/32	3/16	7/32	1/4
2			0.59	0.80	1.04
3			0.72	0.98	1.28
4			0.83	1.13	1.47
5	0.41	0.64	0.93	1.26	1.65
6	0.45	0.71	1.02	1.38	1.80
7	0.49	0.76	1.10	1.49	1.95
8	0.52	0.81	1.17	1.60	2.08
9	0.55	0.86	1.24	1.69	2.21
10	0.58	0.91	1.31	1.78	2.33

Note: Table E-2 was generated assuming that the minimum residual head at the distal orifice is 5 feet when orifices are 1/8 and 5/32 inch in diameter, and 2 feet for larger orifice diameters.

Source: Washington State Department of Health, 2001

Table E-3a: Maximum manifold length in feet for orifice diameters of $\frac{3}{16}$ in. and up with minimum 2 feet of residual head

Maximum Manifold Length (ft)																																					
Lateral Discharge Rate (gpm/lateral)		Manifold Diameter (inches)																																			
		1 1/4						1 1/2						2						3						4						6					
Central Manifold	End Manifold	Lateral Spacing (ft)																																			
		2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10
5	10	4	6	4	6	8	10	6	6	8	12	8	10	10	12	16	18	24	20	22	27	32	42	48	60	34	45	52	72	80	90	72	93	112	144	176	200
10	20	2	3	4				2	3	4	6	8		6	6	8	12	8	10	12	15	20	24	32	30	22	27	32	42	48	60	46	57	72	90	112	120
15	30	2						2	3	4				4	6	4	6	8	10	10	12	12	18	24	20	16	21	24	30	40	40	34	45	52	66	80	90
20	40							2						2	3	4	6	8		8	9	12	12	16	20	12	18	20	24	32	30	28	36	44	54	64	80
25	50													2	3	4				6	9	8	12	16	10	10	15	16	18	24	30	24	30	36	48	56	60
30	60													2	3	4				6	6	8	6	8	10	10	12	16	18	24	20	22	27	32	42	48	60
35	70													2	3					4	6	8	6	8	10	8	12	12	18	16	20	18	24	28	36	40	50
40	80													2						4	6	4	6	8	10	8	9	12	12	16	20	18	21	28	36	40	40
45	90																			4	3	4	6	8	10	6	9	8	12	16	20	16	21	24	30	32	40
50	100																			4	3	4	6	8	10	6	9	8	12	16	10	14	18	24	30	32	40
55	110																			2	3	4	6	8		6	6	8	12	8	10	14	18	20	24	32	30
60	120																			2	3	4	6			6	6	8	12	8	10	12	15	20	24	32	30
65	130																			2	3	4	6			6	6	8	6	8	10	12	15	20	24	24	30
70	140																			2	3	4				4	6	8	6	8	10	12	15	16	24	24	30
75	150																			2	3	4				4	6	8	6	8	10	10	15	16	18	24	30
80	160																			2	3	4				4	6	4	6	8	10	10	12	16	18	24	30
85	170																			2	3					4	6	4	6	8	10	10	12	16	18	24	20
90	180																			2	3					4	3	4	6	8	10	10	12	12	18	24	20
95	190																			2	3					4	3	4	6	8	10	8	12	12	18	16	20
100	200																			2						4	3	4	6	8	10	8	12	12	18	16	20

Instructions: These Tables can be used to determine maximum length of a given diameter manifold *or* to determine required minimum diameter for a given manifold length. Known values must include:

Manifold - lateral configuration (end or central)
 Lateral discharge rate "Q" in gallons per minute
 Lateral spacing in feet

Example A: Central manifold configuration, lateral discharge "Q" = 40 gpm, lateral spacing = 6 ft., manifold diameter = 4 inch; Maximum length = 12 ft.

Example B: End manifold configuration, lateral discharge "Q" = 30 gpm, lateral spacing = 6 ft., manifold length = 18 ft.; Minimum diameter = 3 inch

Source: Washington State Department of Health, 2001

Table E-3b: Maximum manifold length in feet for orifice diameters of $\frac{1}{8}$ in. and $\frac{5}{32}$ in. with minimum 5 feet of residual head

Maximum Manifold Length (ft)																																					
Lateral Discharge Rate (gpm) Rate (gpm/lateral)		Manifold Diameter (inches)																																			
		1 1/4						1 1/2						2						3						4						6					
Central Manifold	End Manifold	Lateral Spacing (ft)																																			
		2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10	2	3	4	6	8	10
5	10	6	9	8	12	16	10	8	12	12	18	16	20	14	18	20	30	32	40	30	39	48	60	72	80	48	63	76	96	120	130	100	129	156	204	240	280
10	20	4	3	4	6	8	10	4	6	8	6	8	10	8	12	12	18	16	20	18	24	28	36	40	50	30	39	48	60	72	80	64	81	100	126	152	180
15	30	2	3	4				4	3	4	6	8	10	6	6	8	12	8	10	14	18	20	24	32	30	22	30	36	42	56	60	48	63	76	96	112	130
20	40	2						2	3	4	6			4	6	8	6	8	10	12	15	16	18	24	30	18	24	28	36	40	50	40	51	60	78	96	110
25	50							2	3	4				4	6	4	6	8	10	10	12	12	18	16	20	16	21	24	30	40	40	34	45	52	66	80	90
30	60							2						4	3	4	6	8	10	8	9	12	12	16	20	14	18	20	24	32	40	30	39	48	60	72	80
35	70							2						2	3	4	6			8	9	12	12	16	20	12	15	20	24	24	30	26	36	40	54	64	70
40	80													2	3	4				6	9	8	12	16	10	12	15	16	18	24	30	24	30	36	48	56	70
45	90													2	3	4				6	6	8	12	8	10	10	12	16	18	24	20	22	30	36	42	56	60
50	100													2	3					6	6	8	6	8	10	10	12	12	18	24	20	20	27	32	42	48	60
55	110													2	3					4	6	8	6	8	10	8	12	12	18	16	20	20	24	28	36	48	50
60	120													2						4	6	8	6	8	10	8	9	12	12	16	20	18	24	28	36	40	50
65	130													2						4	6	4	6	8	10	8	9	12	12	16	20	18	21	28	36	40	50
70	140													2						4	6	4	6	8	10	8	9	12	12	16	20	16	21	24	30	40	40
75	150																			4	3	4	6	8	10	6	9	8	12	16	20	16	21	24	30	32	40
80	160																			4	3	4	6	8	10	6	9	8	12	16	10	14	18	24	30	32	40
85	170																			4	3	4	6	8		6	9	8	12	16	10	14	18	20	30	32	40
90	180																			2	3	4	6	8		6	6	8	12	8	10	14	18	20	24	32	30
95	190																			2	3	4	6	8		6	6	8	12	8	10	14	18	20	24	32	30
100	200																			2	3	4	6			6	6	8	12	8	10	12	15	20	24	32	30

Source: Washington State Department of Health, 2001

Table E-4: Constant “K” values

Nominal Diameter (")	Schedule 40	Class 200	Class 160
1	47.8	66.5	
1.25	98.3	122.9	129.4
1.5	147.5	175.5	184.8
2	284.5	315.2	332.5
2.5	454.1	520.7	551.1
3	803.9	873.3	920.5
4	1,642.9	1,692.7	1,783.9
6	4,826.6	4,677.4	4,932

Source: Washington State Department of Health, 2001

Table E-5: Equivalent length of pipe in feet of friction loss for PVC fittings

Pipe Size (inches)	90° Elbow	45° Elbow	Through Tee Run	Through Tee Branch
.5	1.5	0.8	1.0	4.0
.75	2.0	1.0	1.4	5.0
1	2.25	1.4	1.7	6.0
1.25	4.0	1.8	2.3	7.0
1.5	4.0	2.0	2.7	8.0
2	6.0	2.5	4.3	12.0
2 1/2	8.0	3.0	5.1	15.0
3	8.0	4.0	6.3	16.0
4	12.0	5.0	8.3	22.0
6	18.0	8.0	12.5	32.0
8	22.0	10.0	16.5	38.0

Source: Washington State Department of Health, 2001

Table E-6: Volume of pipes in gallons per foot (gpf)

Nominal Diameter (")	Type of Pipe		
	PR 160	PR 200	Schedule 40
0.75		0.035	0.028
1	0.058	0.058	0.045
1.25	0.098	0.092	0.078
1.5	0.126	0.121	0.106
2	0.196	0.188	0.174
2.5	0.288	0.276	0.249
3	0.428	0.409	0.384
4	0.704	0.677	0.661
5	1.076	1.034	1.039
6	1.526	1.465	1.501
8	2.586	2.485	
10	4.018	3.861	
12	5.652	5.432	

Source: Washington State Department of Health, 2001

References

Converse, J.C. (2000) Pressure Distribution Network Design.
 Washington State Department of Health (2001). Pressure Distribution Recommended Standards and Guidance for Performance, Application, Design, and Operation and Maintenance.

Appendix F: Mound Systems

1 GENERAL

The mound is an above-grade soil absorption system used for wastewater treatment and dispersal. The mound system consists of a septic tank, a dosing chamber and the mound itself. The principal features of the mound are a layer of gravel or aggregate for distribution of the wastewater, a layer of special sand imported to the site, and a layer of the native permeable unsaturated soil on the site. Figure F-1 shows a typical mound system.

The design of the system depends on wastewater characteristics, siting requirements, loading rates and sizing.

Acknowledgements: This paper is adapted from the references shown.

2 EVALUATION OF WASTEWATER CHARACTERISTICS

The first step in designing a mound system is to evaluate the wastewater characteristics. Wastewater quality and quantity are the characteristics most important to designing any soil absorption system, including mound systems. Generally the design is based on typical domestic wastewater effluent having received primary treatment in a septic tank. However, the design of a mound can be altered to suit situations where the effluent has received greater treatment, such as through aerobic treatment units or biological filters. In these cases design alterations include increasing the loading rates to the mound and decreasing vertical separation.

Stronger non-residential wastewater such as from restaurants also requires design alterations. High-strength wastewater must be treated to an equal quality as domestic septic tank effluent before being applied to the mound or else the loading rate must be reduced so that organic loading is no greater than that of domestic wastewater.

The design flow rate is as derived from Section 4 of the Standard Practice Manual (SPM).

3 SITING CRITERIA

The designer must be knowledgeable of the soil horizons and how wastewater will travel in different soil profiles. The siting, size and configuration of a mound will depend on this. More restrictive soil profiles will require longer and narrower mound configurations. Some sites have soil profiles that are inappropriate for mound systems and should not be used for such.

3.1 Vertical Separation

Vertical separation refers to the depth of native permeable unsaturated soil and fill above a limiting layer such as bedrock or the high water table. The depth of native soil above the limiting layer can determine the height of the fill required in the mound, as discussed in Section 5.5 of the SPM.

Bedrock is defined as material in which at least 50% by volume is rock. It can be divided into three classes: crevice, non-crevice semi-permeable or non-crevice impermeable. Treatment can continue within the non-crevice semi-permeable and crevice bedrock types depending on their characteristics. For example, if crevices are filled with soil, treatment may continue although it will be greatly reduced.

3.2 Soil Permeability

The recommended soil basal loading rates can be found in Section 5.6 of the SPM.

3.3 Filled Areas

Filled areas are those in which soil has been brought in to raise the site. Fill texture and structure can range greatly, from sand to clay and from massive to platy, respectively, resulting in variability in the permeability of the soil. Mounds can be located in filled areas, but the increase in variability requires greater inspection of the soil and knowledge of fill in order to predict the movement of wastewater.

3.4 Slopes

The slope of a site does not limit the effectiveness of treatment within a mound. Steeply sloping sites should have long and narrow mounds installed in order to decrease the likelihood of leaks. The only slope restrictions are to do with safety and construction techniques. It is recommended for these purposes that mounds not be built on sites with slopes of greater than 25%. As with any other work, safety is paramount; WCB Regulations must be complied with.

3.5 Flood Plains

Mounds, and all soil absorption systems, should not be located within a flood plain or in any surface depressions where water might pond or drain.

3.6 Horizontal Setbacks

Horizontal setbacks should be the same for mounds as for any other soil absorption system. As a minimum, setbacks should be measured from the edge of the required basal area, and greater actual separation distances might be required to accommodate to the toe of the prescribed slopes on the property.

3.7 Trees and Boulders

Large trees and boulders can inhibit site preparation and soil absorption and are therefore generally avoided. However, if there are no other desirable locations to site a mound, trees can be cut to ground level and stumps and boulders left in place. On sites where tree stumps or boulders occupy a significant area, the mound's basal area should be increased to ensure its ability to accept effluent.

4 DESIGN CRITERIA

Once the designer has sufficient information regarding the wastewater characteristics and soil and site conditions, the design of the mound itself can begin. Mound design requires estimating the site's sand media loading rate, basal loading rate and linear loading rate after which the system can be sized.

4.1 Sand Fill Loading Rate

The maximum design loading rate of the aggregate/sand interface is shown in Table F-1. The loading rate is a function of the level of treatment.

Table F-1: Sand fill loading rates as a function of level of treatment

Level of Treatment	Sand Fill Loading Rate (Lpd/m ²)
Type 1	32
Type 2	64
Type 3	128

4.1.1 Fill Type

The Mound Sand fill media must be carefully selected in order to ensure sufficient treatment of the effluent and to prevent clogging. Very coarse sands will allow the effluent to pass through too quickly and will therefore not adequately treat it while medium to fine sands can result in clogging unless the loading rate is very low, which is impractical. The required fill is very similar to the fine aggregate used for concrete, meeting ASTM Standard C33-97, except that the content of fines is restricted. Table F-2 shows the sieve analysis of the Mound Sand and the C33 specification.

Table F-2: Mound sand and C33 fine aggregate sieve analysis

Sieve Specification	Percent Passing	
	Mound Sand	ASTM C33-97 Fine Aggregate
9.5 mm (3/8 inch)	100	100
4.75 mm (No. 4)	95 to 100	95 to 100
2.36 mm (No. 8)	80 to 100	80 to 100
1.18 mm (No. 16)	50 to 85	50 to 85
600 um (No. 30)	25 to 60	25 to 60
300 um (No. 50)	10 to 30	10 to 30
150 um (No. 100)	<4	2 to 10

4.2 Basal Loading Rate

The calculation of the basal area depends on whether the site is sloping or not. On a sloping site the basal area is $B(A+I)$ and for level sites the basal area is $B(A+I+J)$ where I and J are equal.

Clogging mats do not typically form at the sand/soil interface since most of the organic matter will have been removed by the mound's sand before reaching this layer. The basal loading rates are therefore greater than they would be for septic tank effluent in a non-mound system. The basal loading rates are determined using Table F-3 below.

Table F-3: Selection of a soil hydraulic loading rate (HLR)^v

Method 1 Percolation Rate	Method 2 Soil Texture and Structure (See Note 2)	Method 3 Field-Saturated Hydraulic Conductivity (Kfs) (See Note 3)	Recommended Soil HLR (Lpd / m ²)	
(min / inch)		(cm / day)	Type 1	Types 2 and 3
< 1*	Gravelly to very gravelly sand (single grain).*	> 200*	80	160
1 – 2	Sand (single grain) or gravelly sand (massive).	101 – 200	68	135
3 – 7	Loamy sand (single grain) or sand (massive).	51 – 100	57	115
8 – 12	Well structured sandy loam or silt. Massive loamy sand.	26 – 50	48	96
13 – 20	Well structured loam. Poorly structured sandy loam or silt.	12.6 – 25	40	75
20 – 27	Well structured silt loam or silty clay loam. Poorly structured loam.	6.1 – 12.5	24	36
28 – 45	Well structured sandy clay loam or clay loam. Poorly structured silt loam or silty clay loam.	3.1 – 6.0	12	18
46 – 75*	Well structured sandy clay, silty clay, or clay. Poorly structured sandy clay loam or clay loam.*	1.6 – 3.0*	6	9
76 – 90*	Poorly structured sandy clay or silty clay.*	0.6 – 1.5*	0	3
> 90*	Poorly structured clay.*	< 0.5*	0	0

Footnotes to Table F-3:

* Indicates site conditions for which pressure distribution should be used, regardless of the type of pre-treatment.

- (1) Soil Consistence (USDA): If the moist consistence is Very Firm (VFI) or firmer, or if the dry consistence is Hard (HA) or harder, then the Registered Practitioner should find a location with looser soils, or seek advice from a Professional.
- (2) Soil Structure: For the use in Table 5-3 only, soil structure is classified in the manner described below.

- (3) For Method 3 only, a Professional may calculate a design soil hydraulic loading rate using equations in Appendix C.

Classification of Soil Structure for Selecting a Soil Hydraulic Loading Rate:

- (1) For structured soils: (a) a structure type of granular, blocky, prismatic, or columnar is classed as Well Structured; (b) platy and wedge structures are classed as Poorly Structured.
- (2) For non-structured soils: (a) single grain is classed as Well-Structured; (b) massive is classed as Poorly Structured.

Pressure Distribution:

When using Table F-3, pressure distribution should be required if any one of the following conditions are met:

- (a) The distribution system is a sand mound.

The pre-treatment system is a Type 2 or Type 3 system.

Any soil characteristic indicated in the table with *.

4.3 Hydraulic Linear Loading Rate

The hydraulic linear loading rate is the amount of wastewater applied per linear metre along the natural contour per day.

Once through the clogging layer and in the soil, wastewater moves in the same way any soil water moves. In a free draining soil in a humid environment, or for infiltration systems of sufficient volume, water will flow predominantly downward. Downward moving water reaching a horizon of lower permeability than the rate of precipitation, or precipitation plus added wastewater, will saturate. Some of the saturated zone water will continue downward movement but much will move horizontally down hill through more permeable shallow horizons. The steeper the slope the faster the water moves. If horizons are perfectly level then the water will build a mound beneath the infiltration surface and the groundwater surface created by the mound becomes the hill to drive the horizontal water movement. (Tyler and Kuns)

Horizontally moving effluent, if it does not reach the ground surface, will move through the layer of native permeable unsaturated soil above the impervious layer, that would have been identified in the soil investigation prior to construction of the system.

This soil depth must continue down the slope beyond the toe of the mound. If shallower horizons exist downslope, the entire soil will saturate and the system will fail. The goal is to keep all of the water below the ground surface to provide treatment by the soil and protect against human contact. The thicker the infiltration distance the more water movement possible. (Tyler and Kuns)

The horizontal flow is also dependent on the ability of the soil to move the water horizontally. This is known as saturated horizontal hydraulic conductivity. Saturated hydraulic conductivity is related to soil pore sizes and to the field described soil characteristics utilized to determine wastewater infiltration or loading rates. The more permeable the soil, the greater the horizontal flow. (Tyler and Kuns)

The estimated horizontal flow capacity, in excess of the natural flow, is the hydraulic linear loading rate for the design of the system. Hydraulic linear loading rate is the volume of wastewater the landscape can accept per unit length of system per unit of time. Hydraulic linear loading rate is determined using the field determined slope, horizon thickness and percolation rate, soil texture and structure and hydraulic conductivity, as described in Section 4 of the Standard Practice Manual. Hydraulic linear loading rates may not be limiting to the design of some wastewater infiltration systems. Hydraulic linear loading rate is only limiting if there is a vertical flow restricting horizon below the infiltration surface. In some situations oxygen supply may be limiting.

Table F-4 provides Hydraulic Linear Loading Rates for the sites with the soil characteristics as described in Section 4 of the SPM, for different levels of treatment, different depths of native permeable unsaturated soil to the top of the limiting layer on the site (not including the depth of sand fill) and for different slopes.

Slope and depth of native permeable unsaturated soil are across the top of the table. Slope is the slope of the top of the flow-restricting horizon, which in many soil settings is also the slope of the ground surface. This value must be measured for the area proposed for wastewater infiltration. Infiltration distance may be one horizon, a portion of a horizon or portions of several horizons. The depth of native permeable unsaturated soil to the top of the limiting layer must be confirmed to be available downslope to confirm wastewater will remain below ground. (Tyler and Kuns)

5 MOUND SIZING

Once the loading rates have been determined, the designer can begin sizing the mound. The dimensions required to size the mound are shown in Figure F-1, an illustration of the cross-sectional and plan views of a mound on a sloping site.

5.1 Absorption Area Width

The first dimension to calculate is the width (A) of the absorption area. This is calculated by dividing the linear loading rate (Lpd/m) by the sand loading rate (Lpd/m²) to get the width in metres.

$$A = \text{Linear Loading Rate} / \text{Sand Loading Rate}$$

The width can also be selected by the designer instead of calculated and it is recommended that it be less than 3 metres.

On sloping sites the absorption bed can be divided into multiple beds on different elevations subject to there being a spacing between beds of 90 cm, the total width being at least equal to the required width, and basal area requirements being met. Terracing the


absorption area in this manner might reduce the amount of sand fill to meet the fill slope requirements and the overall footprint of the mound on sloping sites.

5.2 Absorption Area Length

Next, the length (B) of the absorption area can be determined. This is the length of the area along the natural surface contours. It can be calculated by dividing the design flow rate (L/d) by the linear loading rate (Lpd/m) to get the length in metres.

$$B = \text{Design Flow Rate} \div \text{Linear Loading Rate}$$

Figure F-1: Cross section and plan views of a mound system on a sloping site.



Source: Converse and Tyler, 2000.

5.3 Basal Length and Width

The basal length is equal to the length of the absorption area (B), while the basal width is greater. The basal width is equal to A + I on sloping sites and A+I+J on level sites where I and J are equal. These are both calculated as the hydraulic linear loading rate (Lpd/m) divided by the basal loading rate (Lpd/sqm).

$$\frac{A+I \text{ (for sloping sites) or } A+I+J \text{ (for level sites)}}{\text{Linear Loading Rate} \div \text{Basal Loading Rate}} =$$

5.4 Mound Fill Depth

As previously discussed, the depth (D) of the mound (distance between the distribution system and the soil surface) depends on both the required separation distance to a limiting layer and the depth from the surface to any such limiting layer. The depth is calculated as the difference between the required separation distance and the depth from the soil surface to the limiting layer.

5.5 Downslope Mound Fill Depth

The downslope mound fill depth (E) is the distance between the absorption area and the soil surface on the downslope edge. This depth of fill is what keeps the absorption area level. It depends on the original slope of the site and the width (A) and depth (D) of the absorption area. It is calculated as the slope (%) multiplied by the absorption area width (A) plus the mound fill depth (D) as calculated above.

$$E = D + A (\text{Slope } \%)$$

5.6 Absorption Area Thickness

F is the thickness of the absorption area, including the aggregate material both above and below the distribution laterals as well as the diameter of the pipes. It is recommended that this value be at least 23 cm: 15 cm of aggregate below and 8 cm of aggregate above the distribution pipe and 2.5 cm for the pipe itself.

5.7 Mound Cover

Mound covers are required to allow for vegetation to grow and to prevent the surface above the absorption area from eroding. However, the soil must still be able to provide oxygen to the absorption area below. It is recommended that sandy loam, loamy sands and silt loams be used in the mound cover for this purpose. Clay loam, silty clay loam and clay soils are not recommended.

In Figure F-1, G and H respectively indicate the depth of the mound cover over the edges and the centre of the absorption area. The depth for G is recommended as 15 cm. The depth for H is recommended as 30 cm so that there is enough of a slope to encourage

runoff; however a full 15 cm of difference in height is not required if the absorption area is narrow. These depths are lower than the traditionally recommended depth of 30 to 45 cm so that more oxygen can be transferred.

5.8 Side Slope Widths

For a sloping site, the downslope width (I) and upslope width (J) depend on the depth of the mound at the downslope and upslope edges, respectively, of the absorption area, the desired final slope and the original slope of the site. The desired final slope is usually to be 3:1 for safety reasons, such as for when mowing. Up and down-slope correction factors are given in Table F-5, based on the original slope. The slope widths are calculated as follows:

$$I = 3 (E+F+G) \text{ (Slope Correction Factor)}$$

$$J = 3 (D+F+G) \text{ (Slope Correction Factor)}$$

On level sites both slope widths are equal and depend only on the depth of the mound at the edges of the absorption area and the desired slope. Slope widths could also be calculated by subtracting the absorption area width (A) from the basal width (A+I for sloping sites or A+I+J for level sites where I and J are equal).

5.9 End Slope Length

The end slope length (K) also depends on the same factors as the widths of the side slopes except that it considers the depth of the mound at the centre of the absorption area instead of the edges. It also depends on a suggested slope of 3:1. Typically, the slope length is 2.5 to 3.6 metres.

5.10 Overall Length and Width

The overall length is calculated as the absorption area length (B) plus two times the end slope length (K). The overall width is equal to A+I+J where I and J are different for sloping sites and equal for level sites.

6 DESIGN A PRESSURE DISTRIBUTION NETWORK

A pressure distribution network, including the distribution piping, dosing chamber and pump, must be designed using the procedure described elsewhere in the SPM.

- Use 4.7 mm ($\frac{3}{16}$ ") holes for effluent from a septic tank with effluent filter. For higher levels of treatment, 3.1 mm ($\frac{1}{8}$ ") holes could be used.
- Using 0.56 m² of sand infiltrative surface per orifice
- Provide easy access to flush the laterals such as turn-ups at end of laterals.
- Dose volume at 5 times the lateral pipe volume and not to exceed 20% of the design
- Timed dosing is preferred, which requires surge capacity in the septic tank/pump chamber.

7 MOUND CONSTRUCTION

The following is from Converse, J.C. and Tyler, E.J. (2000), and represents the current thinking on mound construction:

A construction plan for any on-site system is essential. A clear understanding between the site evaluator, the designer, contractor and inspector is critical if a successful system is installed. It is important that the contractor and inspector understand the principles of operation of the mound system before construction commences otherwise the system will not function as intended. It is also important to anticipate and plan for the weather. It is best to be able to complete the mound before it rains on it. The tilled area (basal area) and the absorption area must be protected from rain by placing sand on the tilled area and aggregate on the absorption area prior to precipitation. There are several different ways to construct a mound as long as the basic principles and concepts are not violated. The following are suggested construction steps:

- (1) The mound must be placed on the contour. Measure the average ground surface elevation prior to tillage along the up slope edge of the absorption area. This contour will serve as the base line for determining the elevation of the bottom of the absorption area.
- (2) Grass, shrubs and trees must be cut close to the ground surface and removed from the site. In wooded areas with excess litter, it is recommended to rake the majority of it from the site. Do not pull out the stumps and do not remove the sod or the top soil or boulders.
- (3) Determine where the force main from the pump chamber enters the mound. It will either be center feed or end feed. For long mounds, center feed is preferred and all end feeds can be made into center feed. For center feed the force main can enter from the up slope center (preferred), the down slope center or exit the native soil at the end and be placed horizontally on a slight slope in the sand beneath the aggregate or just up slope of the aggregate. If it must be brought in from the down slope side, especially on slowly permeable soils with high seasonal saturation where the effluent flow may be horizontal, it should be brought in perpendicular to the side of the mound with minimal disturbance to the down slope area. All vehicular traffic must be kept in a very narrow corridor. Minimal damage is done if the soil is dry. Soil should be packed around the pipe and anti-seep collars should be installed to minimize effluent and water following the pipe. Entering from the down slope center should be the last choice on sites that are slowly permeable with shallow seasonal saturation.
- (4) The footprint of the mound must be tilled only when the soil moisture is within a satisfactory range. The satisfactory moisture range, to a depth of 6-7", is defined as where the soil will crumble and not form a wire when rolled between the palms. The purpose of tillage is to roughen the surface to allow better infiltration into the top soil. It also provides more contact between the sand and the soil. Excessive tillage will destroy soil structure and reduce

infiltration. The preferred methods in order of preference are i) using chisel teeth mounted on a backhoe which can be easily removed, ii) using a chisel plough pulled behind a tractor, and iii) using a backhoe bucket with short teeth which requires flipping the soil. Normally it takes much longer to use the backhoe bucket than a chisel teeth mounted on the backhoe with the added cost quickly recovered. Mouldboard ploughs have been used successfully but are the least preferred. Rototillers are prohibited on structured soils but may be used on unstructured soils such as sand to break up the vegetation. However, they are not recommended. All tilling must be done following the contour.

If a platy structure is present in the upper horizons, the tillage depth should be deep enough to try to break it up without bringing an excessive amount of subsoil to the surface. Deep tilling for the sake of deep tilling is not recommended. Till around the stumps without exposing an excessive amount of roots. Chisel teeth, mounded on a backhoe, is the preferred and an easier method for tilling around stumps. Stumps are not to be removed but some small ones may be inadvertently pulled out during tilling. If so, remove them from the site. If there are an excessive number of stumps and large boulders, the basal area should be enlarged or another site selected but that is the rare occasion.

- (5) Once the site has been tilled, a layer of sand must be placed before it rains. Driving on the exposed tilled soil is prohibited so as not to compact it or rut it up. Sand should be placed with a backhoe (preferred) or placed with a blade and track type tractor. A wheeled tractor will rut up the surface. **All work is to be done from the up slope side so as not to compact the down slope area especially if the effluent flow is horizontally away from the mound.**
- (6) Place the proper depth of sand, then form the absorption area with the bottom area raked level. The sand should be reasonably compacted in the trench area to minimize settling. A good backhoe operator can form the trench with minimal hand work.
- (7) Place a clean sound aggregate to the desired depth. **Limestone is not recommended.** If chambers are used, proper procedures must be performed to keep the chambers from settling into the sand. Procedures are available from the manufacturers that include compacting the sand to a certain specification and placing a coarse netting on the compacted surface prior to chamber placement.
- (8) Place the pressure distribution network with holes located downward and cover it with 2.5 cm (1 in.) of aggregate. Connect the force main to the distribution network. If chambers are used, the pressure distribution laterals must be suspended from the chambers with holes upward. Provisions must be made to allow the laterals to drain after dosing. This is accomplished by having several holes located downward or sloping the pipe in the chamber toward the force main. The laterals and force main must drain after each dose.

- (9) Cover the aggregate with a geotextile synthetic fabric.
- (10) Place suitable soil cover on the mound. There should be 15 cm (6") on the sides and shoulder (G) and 30 cm (12") on the top center (H) after settling. The soil cover should support vegetation. If not, provisions must be made to control erosion.
- (11) Final grade the mound and area so surface water moves away from and does not accumulate on the up slope side of the mound. Use lightweight equipment.
- (12) Seed and mulch the entire exposed area to avoid erosion. Advise the homeowner on proper landscaping. The top of the mound becomes dry during the summer and the down slope toe may be wet during the wet seasons. Avoid deep rooted vegetation on the top of the mound to minimize root penetration into the distribution network
- (13) Inform homeowner about the type of system, maintenance requirements and do's and don'ts associated with on-site soil based systems.

Table F-4: Linear hydraulic loading rates for mound systems

Soil Characteristics			Linear Hydraulic Loading Rate (Litres of Design Flow per Day per Metre of Mound Length)								
			Slope								
Method 1	Method 2	Method 3	0-4 %			5-9 %			>10 %		
Percolation Rate	Soil texture and structure	Field-Saturated Hydraulic Conductivity (Kfs)	Depth of Native Permeable Soil (mm)			Depth of Native Permeable Soil (mm)			Depth of Native Permeable Soil (mm)		
Min / inch		cm / day	200-305	305-610	>610	200-305	305-610	>610	200-305	305-610	>610
< 1*	Gravelly to very gravelly sand (single grain)**	> 200*	no	no	no	no	no	no	no	no	no
1 – 2	Sand (single grain) or gravelly sand (massive)	100 – 200	37	43	50	45	51	57	62	74	87
3 – 7	Loamy sand (single grain) or sand (massive)	50 – 100	37	43	50	45	51	57	62	74	87
8 – 12	Well structured sandy loam or silt.	25 – 50	37	43	50	45	51	57	50	62	74
	Massive loamy sand.										
13 – 20	Well structured loam.	12.5 – 25	37	43	50	41	47	53	45	51	57
	Poorly structured sandy loam or silt.		25	31	37	27	34	40	30	36	42
20 – 27	Well structured silt loam or silty clay loam.	6.0 – 12.5	25	31	37	27	34	40	30	36	42
	Poorly structured loam.										
28 – 45	Well structured sandy clay loam or clay loam.	3.0 – 6.0	25	31	37	27	34	40	30	36	42
	Poorly structured silt loam or silty clay loam.										
46 – 75*	Well structured sandy clay, silty clay, or clay.	1.5 – 3.0*	no	no	no	no	no	no	no	no	no
	Poorly structured sandy clay loam or clay loam.*		no	no	no	no	no	no	no	no	no
76 – 90*	Poorly structured sandy clay or silty clay.*	0.5 – 1.5*	no	no	no	no	no	no	no	no	no
> 90*	Poorly structured clay.*	< 0.5*	no	no	no	no	no	no	no	no	no

Footnotes to Table F-4

* For these soils, with a very high or very low permeability, a design linear loading rate must be calculated by a qualified Professional.

Soil Consistence (USDA): If the moist consistence is Very Firm (VFI) or firmer, or if the dry consistence is Hard (HA) or harder, then the Registered Practitioner should find a location with looser soils, or seek advice from a Professional.

Soil Structure: For the use in Table F-4, soil structure is classified in the manner described below.

Classification of Soil Structure for Selecting a Linear Loading Rate:

For structured soils: (a) a structure type of granular, blocky, prismatic, or columnar is classed as Well Structured; (b) platy and wedge structures are classed as Poorly Structured. For non-structured soils: (a) single grain is classed as Well-Structured; (b) massive is classed as Poorly Structured.

Ref.: Adapted from Tyler, E. J. and Kuns, L. K. (circa 2000)

Table F-5: Down slope and up slope correction factors

Slope %	Down Slope Correction Factor	Up Slope Correction Factor
0	1	1
1	1.03	0.97
2	1.06	0.94
3	1.1	0.92
4	1.14	0.89
5	1.18	0.88
6	1.22	0.85
7	1.27	0.83
8	1.32	0.8
9	1.38	0.79
10	1.44	0.77
11	1.51	0.75
12	1.57	0.73
13	1.64	0.72
14	1.72	0.71
15	1.82	0.69
16	1.92	0.68
17	2.04	0.66
18	2.17	0.65
19	2.33	0.64
20	2.5	0.62
21	2.7	0.61
22	2.94	0.6
23	3.23	0.59
24	3.57	0.58
25	4	0.57

References

Converse, J.C. and Tyler, E.J. (2000) *Wisconsin Mound Soil Absorption System: Siting, Design and Construction Manual*. Paper #15.24. Small Scale Waste Management Project. University of Wisconsin – Madison.

Tyler, E. J. and Kuns, L. K. (circa 2000) *Designing With Soil: Development and Use of a Wastewater Hydraulic Linear and Infiltration Loading Rate Table*. Paper #4.42. Small Scale Waste Management Project. University of Wisconsin – Madison.

Appendix G: Flow Trials

THE FLOW TRIAL

Discussion

The flow trial is not a be-all-and-end-all test, nor is it accurate under all conditions. The results of a flow trial should always be interpreted within the context of the entire inspection. For example, if there is an obvious cave-in over the soil absorption system, the system clearly needs a major repair and a flow trial will not provide any useful information.

The test will not find every failure condition nor provide any guarantee that the existing sewage disposal system will continue to perform.

A flow trial should **NOT** be performed in the following situations:

(1) Evidence of structural damage to the system such as:

- broken tee or baffle
- cracked tank

In this case, refer the owner to a repair Professional.

(2) The system is showing obvious signs of failure, as the flow-trial procedures may actually aggravate the problem.

(3) The system is such that flow into it is limited in volume and time, such as a system with a dosing device or a recirculating sand filter. Such a system can be damaged by excessive flooding.

Some situations may not provide reliable results for a flow trial. Examples include:

(1) The home was unoccupied for a significant period of time over the past 12 months. In this situation, a failing soil absorption system may have been temporarily renovated during the extended lack of use and will accept the full flow-trial volume. However, when the system starts receiving flows typical of an occupied home, the system may once again show signs of failure.

(2) The system has had a recent hydrogen peroxide treatment (usually evidenced by chemical scouring or a bleached-out appearance on concrete components). In this situation, the system may have been restored temporarily and will accept the full flow-trial volume. Inspectors should be mindful that use of hydrogen peroxide generally indicates an attempt to fix a major system failure, which is likely to recur.

A flow trial is typically performed using in-home water fixtures to provide the necessary volume of water. It may also be performed at the inlet of the septic tank with a garden

house inserted into the inspection port. **Be sure the hose is not immersed in the wastewater in the tank.**

In some situations however, it is recommended to perform the flow trial at the septic tank outlet. These include:

(1) Over-accumulation of solids:

- depth of combined solids is greater than 85 cm (34");
- depth of scum is greater than 27.5 cm (11"); or
- depth of sludge is greater than 65 cm (26").

In this situation, a flow trial performed at the inlet could result in solids carry over to, and clogging of, the soil absorption system.

(2) The inspector has not measured the depth of solids and the system has not been pumped in over 3 years. An adequately sized, conventional system, which has been pumped in the last 3 years, is unlikely to have an over-accumulation of solids; however, inspectors may wish to measure solids for added certainty.

Before performing the flow trial, the system should be inspected. The volume of water required for the flow trial should also be calculated as described in the following section.

Calculating the flow trial volume

Normal wastewater flows vary over the course of a day, peaking during the morning and evening hours when people are most likely to use the kitchen, bathroom and laundry facilities. The greatest flow that may enter a system during an hour of time is called the peak one-hour flow. As it is typically the most stressful condition experienced by a system, the peak one-hour flow is also the condition that the flow trial is designed to approximate (i.e., peak one-hour flow = flow trial volume).

The peak one-hour flow can be estimated as 8 times the average hourly flow or one third the daily flow. Systems in British Columbia are designed based on the number of bedrooms. Therefore, flow trial volumes can be calculated as one third the design flow. Table G-1 indicates flow trial volumes for homes relative to number of bedrooms and design-flow volumes.

Table G-1: Maximum flow trial volumes relative to number of bedrooms and design flow

No. of Bedrooms Single Family Dwelling	Design Flow		Flow Trial Volume	
	L/day	Imp. Gal./day	L	Imp. Gal.
1 – 2	1136	250	375	83
3	1363	300	450	99
4	1704	375	562	124
5	2045	450	675	149
6	2500	550	825	182

Flow trial procedures

The following are procedures for a flow trial. Inspectors should keep in mind that a flow trial requires a large volume of water, which creates a good condition for dye tracing. If both a dye tracing and flow trial are to be done, an inspector should perform them together to avoid waste (to determine if dye tracing is necessary refer to Section 4.9, “Dye Tracing for Confirming Treatment Bypasses” of the Homeowner’s Guide).

- (1) Calculate flow trial volume required based on system design (see previous section).
- (2) Ask occupants to refrain from using any plumbing fixtures (e.g., sinks, toilets, washing machines, dish washers, etc.) during the flow trial.
- (3) Consider the condition of the septic tank (refer to Section 4.1.1, “Examining the external condition of septic tanks” of the Homeowner’s Guide and to the first section, “Limitations of the flow trial”). If the system is not in good working order, do not proceed with the flow trial. If the inspector opts not to do the flow trial, then the tank should be pumped and the inspector should refer the system owner to a repair Professional.

In general, if a system has been pumped in the last three years, then it can be assumed that there will be no solids carryover during a flow trial. If no pumpout record is available, the inspector should measure the depth of both the scum and sludge layers.

- (4) If the system appears to be in working order, the flow trial volume may be added by opening water taps in the house or with a garden hose inserted in the inlet or the outlet inspection port of the septic tank. **Be sure the hose is not immersed in the wastewater in the tank.** The flow trial volume (refer to the preceding section, “Calculating the flow trial volume”) may be added at a rate of between 18 - 36 L (4 - 8 imp.gal.) per minute.

If the house has a water metre, then the metre may be used to measure flow (refer to Section 6.1, “Estimating Water Use” of the Homeowner’s Guide). (Be sure to note the volume unit of flow on the metre.) If a household water metre is not present, an in-line flow metre may be used on a garden hose to measure flow rate. If no metreing device is available, flow rate from a garden hose may be estimated by opening the tap fully and timing the fill up of a 20 L (4.5 imp.gal.) bucket (refer to equation 6.2 “Flow Rate” in Section 6.2.2 of the Homeowner’s Guide, for more details).

If dye tracing is being performed on the system, dye should be added to the outlet of the septic tank during this step.

- (5) If water begins to back up in the septic tank (i.e., rises more than 5 cm (2 in) above the outlet bottom), stop the flow of water. This is an indication of system failure. Inspectors should note that when first adding flow to the soil

absorption system, a small rise in water level (2.5 cm (1 in)) will occur in the septic tank. This is not a backup.

- (6) Inspect the soil absorption system, all property areas, and adjacent ditches for evidence of failure (i.e., surfacing of water) and appearance of dye if used.
- (7) The system would appear to be functioning properly if it accepts the full flow trial volume without failure. If the system did not accept the full flow-trial volume, refer the owner to a repair Professional. Record the results on an inspection report form.

Factors to consider when interpreting flow trial results include:

- (a) evidence of a heavy object placed over the soil absorption system.
- (b) one component or more exposed as a result of soil erosion.

Appendix H: Testing

1 HYDROSTATIC TESTING

Water-pressure testing determines a tank's watertightness by maintaining a certain water level for one hour after a 24-hour absorption period.

Be careful when performing hydrostatic tests on plastic and fiberglass tanks as they gather much of their strength from the soil support. For all mid-seam tanks, keep the backfill near the mid-seam, but leave the seam itself exposed to monitor the test.

The following is a suggested water testing procedure for tanks. Note that this test does not evaluate the tank's ability to withstand external pressures: that issue must be assured through adequate engineering design.

- (1) Plug the inlet and outlet pipes with a watertight plug, pipe and cap or other seal. Seal the pipes away from the tank to test any pipe connections that may be of concern.
- (2) If testing a mid-seam tank, ensure that the seam is exposed for the water test.
- (3) Fill the tank to the top.
- (4) If the tank has a riser, add water into the riser to a maximum of 5.0 cm above the tank/riser seam. Care must be taken not to overfill as the top section of a two-piece tank may become buoyant.
- (5) Measure and record the level of the water.
- (6) Let the tank sit for 24 hours. Any obvious leakage during this time should be evaluated and remedied by the application of a suitable sealing compound.
- (7) If the test reveals leaks that cannot be repaired, the tank is considered unacceptable.
- (8) Refill concrete tanks to original level after 24 hours as they will absorb some water.
- (9) Check again after 24 hours. If less than 4 litres is lost in a concrete tank, the leak test is considered acceptable.

Tables H-2 and H-3 provide information for calculating volumes in square and round risers.

Table H-2: Depth change equivalent to four litres in round risers of various interior diameters.

Riser Diameter (cm)	Depth (cm) Equal to Four Litres
46	2.4
61	1.4
76	0.9
91	0.6

Table H-3: Depth change equivalent to four litres in square risers of given interior dimensions.

Riser Dimensions (cm)	Depth (cm) Equal to Four Litres
18 x 18	1.9
24 x 24	1.1
36 x 36	0.5

When performing hydrostatic testing in cold climates, there are a few important points to consider. First, water is its densest at about 4 degrees C (just above freezing), so water put into a tank at 10-20 degrees C (typical of groundwater) and left in the tank overnight at freezing temperatures will drop the level in the tank a substantial amount (about 2% or 11 litres in a 5,600 litre tank). A 'loss' of 11 litres in the risers will look like a leak. Additionally, water used in the test will freeze and expand by approximately 9%. If the site is not occupied quickly the tank may crack as a result of the test itself.

2 VACUUM TESTING

Vacuum testing verifies that a tank is watertight if it holds 90 percent of a two-inch vacuum of mercury for two minutes.

Vacuum testing of tanks requires less time than hydrostatic testing and can be performed without having water available on the site. Testing should be done on the tank in its ready-to-use state (i.e., pipes in the inlet and outlet, risers with lids, etc.) In this test all pipe penetrations, manholes and risers are sealed airtight and a special insert is sealed on one of the tank manholes. Using a pump, air is evacuated through this insert to a standard vacuum level and the reading on a vacuum gage is recorded. Be careful not to exceed the recommended vacuum level. It is possible to damage or implode a tank.

The 2003 National Precast Concrete Association (US) standard states: "The recommended [vacuum test] procedure is to introduce a vacuum of 4 inches of mercury. Hold this pressure for 5 minutes. During this initial 5 minutes, there is an allowable pressure equalization loss of up to a half-inch of mercury. If the pressure drops, it must be brought back to 4 inches and held for a further five minutes with no pressure drop."

If a tank will not hold the vacuum, leaks must be located and repaired. The test can then be repeated. If the tank cannot be repaired and rendered watertight, it should be replaced.

Note that vacuum testing of concrete tanks draws seams together for a positive mastic seal, assuming there are no other problems. With any tank, collapse, deflection, deformation, or cracking indicate a poor quality tank. It is important to test the entire system: tank, pipe sleeves, risers, inspection ports and lids.

3 TESTING EXISTING TANKS

It is more difficult to check watertightness in an existing septic tank. Adequate testing requires a period of several hours to a day or more without inflow to the tank and sealing off inlet and outlet pipes. Seal the line at the distribution box (or other appropriate place in the case of secondary treatment units) and at the cleanout between the building and the tank. Apply vacuum or water as desired. If there are no leaks, the entire system passes in one step. If there are leaks, successive tests will locate the source or sources. Although actual testing of existing tanks may be impractical, much can be discerned by a thorough inspection of a tank both before and after it has been pumped out. Most tanks built using older methods of construction (such as built-in-place block or brick tanks) would typically not be watertight or structurally sound and probably cannot reasonably be repaired. In some cases it may be possible to do more to check existing tanks. If the soil around the tank is saturated, the tank contents can be pumped down and observations made over the next few hours to detect leakage into the tank around pipe penetrations, seams or through breaks in the tank. Caution should be exercised, however, as high groundwater may cause empty tanks to become buoyant and float out of the ground. Alternately, excessive soil pressure may collapse a tank. In some cases, it may be necessary to excavate completely around the tank to make a visual inspection for leaks. If there is any doubt about the integrity of the existing tank, it should be replaced.

Appendix I: Endnotes

ⁱ References:

Cogger, Craig G., 1989. Seasonal high water tables, vertical separation, and system performance. In Proceedings: 6th Northwest On-Site Wastewater Treatment Short Course. September 18 - 19, 1989.

Epp, P.F., 1984. Soil Constraints for Septic Tank Effluent Absorption. MOE Manual 5. United States Department of Agriculture, Natural Resources Conservation Service, 2001. National Soil Survey Handbook. Title 430-VI.

ⁱⁱ Editorial Note

Design manuals and research papers recommend various methods to estimate or select a design soil hydraulic loading rate (HLR) for an onsite sewerage system. With any method used, the intent should be to try to estimate the long-term acceptance rate (LTAR) of the native soil, considering the tendency for soil clogging and biomat formation to gradually reduce the effective permeability, or hydraulic conductivity, of the soil at or near the infiltration surface. The three main methods that are well-documented in manuals and research papers are:

- percolation tests, with empirical tables to calculate either the drainfield length or the HLR;
- soil texture, or texture and structure, used to select a soil HLR from an empirical table;
- tests of the soil's hydraulic conductivity (K), with a formula or table to calculate the soil HLR from K.

Registered Planners and Professionals should use at least two of these three methods when selecting a design HLR.

ⁱⁱⁱ Reference:

Loudon, T.L., T.R. Bounds, J.C. Converse, T. Konsler and C. Rock. 2005. Septic Tanks Text in (D.L. Lindbo and N.E. Deal eds.) Model Decentralized Wastewater Practitioner Curriculum. National Decentralized Water Resources Capacity Development Project. North Carolina State University, Raleigh, NC.

^{iv} Editorial Note

Filling the tank will prevent caving in, collapse and floatation. Organic materials are not to be used for this purpose as they can decay, possibly leading to caving in or collapse and can produce toxic and possibly explosive gases.

^v Temporary Editorial Comment on Draft

Discussion of Wastewater Loading of Sand Mounds

For the planning of a sand mound, there are two separate hydraulic loading rates that must be calculated. The first is the hydraulic loading rate for the treatment system effluent infiltrating into the C-33 sand at the base of the infiltration trenches or bed. The second is the filtered water that seeps out of the C-33 sand mound into the underlying native soil. Each of these design aspects must be considered separately.

The filtered water that seeps from the sand mound into the native soil can be considered of higher quality, or more treated, than the effluent that entered the sand mound.

If the vertical thickness of C-33 sand, from the infiltration surface to the native soil surface, is more than 45 cm (18 inches), then a sand mound will normally reduce BOD by 80% to 90%. That is, when Type 1 effluent (BOD ~ 130 mg/L) is discharged to the sand mound, the filtered effluent reaching the native soil can be considered to be Type 2 effluent (BOD < 26 mg/L). If Type 2 effluent (BOD < 45 mg/L) is discharged to the sand mound, Type 3 effluent (BOD < 9 mg/L) can be expected to seep into the native soil.

If the vertical thickness of the sand mound is more than 75 cm (30 inches), manuals and reports show that a properly operating sand mound can be expected to remove 90% to 95% of the effluent BOD. That is, Type 1 effluent discharged to the sand mound produces nearly Type 3 effluent (< 13 mg/L) at the base of the sand mound (US EPA, 2002; Crites and Tchobanoglous, 1998; Washington State, 1999).

When designing a sand mound, the basal area of the mound must be based on the expected effluent quality at the base of the mound, and the long-term acceptance rate (LTAR) of the native soil present at the base of the mound. Table F-3 may then be used for selecting a soil HLR for sizing of the base of the sand mound.